

**TOWN OF PARADISE  
ONSITE WASTEWATER MANAGEMENT ZONE  
EVALUATION REPORT**

**Permit Number:** OS18-02173  
**AP Number:** 050-210-083-000  
**Property Address:** 1630 GRAYSTONE CT  
**Occupancy Type:** Single Family

**Primary Contact:** REQUESTED BY BLUE TEAM REALTY  
 C/O SHERRI PALADE @ BLUE TEAM; PRE-SALE  
 PARADISE, CA 95969

**Evaluation Date:** 03/22/2018

**Evaluator:** MARK MUHLBAIER  
 PARADISE SANITATION CO

**Evaluation Results**

Pump Only	No
Access Risers in Place	No
Sanitary Tee - Inlet	Yes
Scum Depth, Inlet Compartment	7 Inches
Sludge Depth, Inlet Compartment	8 Inches
Structural Tank Condition	Good
Liquid from Operating Level	Normal
Baffle Condition	Good
Tank Volume	1500 Gallons
Sanitary Tee - Outlet	Yes
Scum Depth, Outlet Compartment	0 Inches
Sludge Depth, Outlet Compartment	5 Inches
Tank Material	Concrete
Septic Tank Pumping Required	No
Was Septic Tank Pumped	No
Depth to Septic Tank Access Lid - Inlet	13 Inches
Depth to Septic Tank Access Lid - Outlet	13 Inches
Effluent Pump	No
Effluent Line Diverter Valve	No
Well on Property	No
Common Area/Community Absorption Field	No
Absorption Field Type	Standard
Surfacing Effluent	No
Hydraulic Load Test	Yes
Hydraulic Load Test - Results	Good
Down Slope Seepage	No
Saturated Absorption Field	No
Multiple Systems	No
Graywater Discharge	No

**Evaluator Comments**

Tank appears to be structurally sound and absorption field is working normally.

### Location Sketch

