

M & W Pumps, Inc.

1226 W. Furukawa Way
Santa Maria CA 93458

PH: 805-925-1147 FAX: 805-928-6286

Invoice

Bill To
Gary Wells 10205 Suey Creek Road Santa Maria CA 93454

Date	Invoice #
5/24/2017	11913

P.O. Number	Terms	Ship	Via	FOB
	DUE ON RECEIPT	5/16/2017	Our Truck	
Quantity	Description	Price Each	Amount	
1	WELL TEST Flow tested well. 17gpm @ 82' Test results enclosed.	600.00	600.00	

Thank you for your business.

Subtotal \$600.00

Sales Tax (8.0%) \$0.00

NOTE: A FINANCE CHARGE OF 1.5% PER MONTH (18% PER YEAR) WILL BE ADDED TO ALL ACCOUNTS PAST DUE BASED ON EXISTING CREDIT TERMS.

Total Amount Due \$600.00

Due Date 5/24/2017

If you have any questions regarding this invoice please call Lisa at 805-925-1147 or email info@mwpumps.com.

M & W Pumps, Inc.

1226 W. Furukawa Way
Santa Maria, CA 93458
PH (805) 925-1147 FAX (805) 928-6286
LICENSE # C57-752893

Pump Test Report

CUSTOMER Gary Wells DATE: 5/16/2017
ADDRESS 10205 Suey Creek Road
CITY & STATE Santa Maria CA

TEST INFORMATION

TIME	PUMPING LEVEL	GALLONS PER MINUTE
12:00	32'	17
1:00	72'	17
2:00	82'	17
3:00	82'	17
4:00	82'	17

WELL INFORMATION

WELL SIZE 6" pvc WELL DEPTH Unknown
TEST PUMP SIZE Unknown, used existing customer pump, 3/4hp
STANDING WATER LEVEL 32' PUMPING LEVEL 82'
HOURS RUNNING 4
TEST START 12pm TEST END 4pm

ADDITIONAL INFORMATION Test reflects well capacity on day of test. No guarantee on future well yield.

COMPLETED BY: Michael Schiada