

**TOWN OF PARADISE
 ONSITE WASTEWATER MANAGEMENT ZONE
 EVALUATION REPORT**

Permit Number: OS18-03208
AP Number: 051-092-021-000
Property Address: 665 BILLE RD
Occupancy Type: Single Family

Primary Contact: RHEA DOUVUKE
 DOUVILLE RHEA M
 665 BILLE RD
 PARADISE, CA 95969

Evaluation Date: 04/26/2018

Evaluator: ERIC HEGENBART
 HEGENBART SEPTIC TANK
 CLEANING

Evaluation Results

Pump Only	No
Access Risers in Place	No
Sanitary Tee - Inlet	Yes
Scum Depth, Inlet Compartment	0 Inches
Sludge Depth, Inlet Compartment	8 Inches
Structural Tank Condition	Good
Liquid from Operating Level	Normal
Baffle Condition	Good
Tank Volume	1500 Gallons
Sanitary Tee - Outlet	Yes
Scum Depth, Outlet Compartment	0 Inches
Sludge Depth, Outlet Compartment	2 Inches
Tank Material	Concrete
Septic Tank Pumping Required	No
Was Septic Tank Pumped	No
Depth to Septic Tank Access Lid - Inlet	18 Inches
Depth to Septic Tank Access Lid - Outlet	20 Inches
Effluent Pump	No
Effluent Line Diverter Valve	No
Well on Property	No
Common Area/Community Absorption Field	No
Absorption Field Type	Standard
Surfacing Effluent	No
Hydraulic Load Test	Yes
Hydraulic Load Test - Results	Excellent
Down Slope Seepage	No
Saturated Absorption Field	No
Multiple Systems	No
Graywater Discharge	No


Evaluator Comments

Water line over inlet lid. Large lid 100 + pounds with plastic handles. Mulberry could effect system in future

Location Sketch

EVALUATOR SIGNATURE: C. J. [Signature] DATE: 4/26/18

LOCATION OF SEPTIC TANK & ABSORPTION FIELD



PARCEL ADDRESS: 665 B. 1/2 rd.

*Show all existing structures, wells, water courses, decks, porches, sidewalks and driveways.

TOWN OF PARADISE USE ONLY

The onsite wastewater treatment and disposal system is in substantial compliance with Chapter 13.04 of the Paradise Municipal Code and the Town of Paradise Manual for the Treatment of Wastewater: YES NO

TOWN OF PARADISE ONSITE WASTEWATER MANAGEMENT ZONE
 5555 SKYWAY PARADISE, CA 95969
 OFFICE: (530) 872-6291 FAX: (530) 877-5059