



State License No. C57 432680  
P.O. BOX 845  
ATASCADERO, CA 93423  
805-466-1271

Name	RICHARD PAULDING	Date	6/20/2017
Mailing Address	7020 ANDREWS VINEYARD DR - CRESTON, CA 93432	Phone	
Job Location	9770 GOLDEN POND - CRESTON	Fax	
Well Size	5"	Depth	382'
Tested by	J. COOK	Rate of Flow (gpm)	3.5
		Duration	4 HOUR + RECOVERY
		Static Level	64.4'

### Well Test Report

<u>Date</u>	<u>Time</u>	<u>Water Level (FT)</u>	<u>G.P.M.</u>
6/15/2017	12:00PM	64.6	4.2
	12:05	84.5	4.2
	12:10	88.5	4.2
	12:20	104.8	3.5
	12:30	115.3	3.5
	12:45	125.0	3.5
	1:00	143.2	3.5
	1:30	165.3	3.5
	2:00	182.4	3.5
	3:00	208.2	4.2
	4:00	227.2	4.2

### Recovery

<u>Date</u>	<u>Time</u>	<u>Water Level (FT)</u>
6/15/2017	4:00PM	227.2
	4:05	224.0
	4:10	221.4
	4:15	218.0

Additional Comments:  
PUMP WAS SET @ 370'

Thank you,

Ned M. Thompson



State License No. C57 432680  
P.O. BOX 845  
ATASCADERO, CA 93423  
805-466-1271

## PUMP INFORMATION FOR OUR RECORDS

Name	RICHARD PAULDING	Date	6/15/2017
Address	7020 ANDREWS VINEYARD DR - CRESTON, CA 93432	Code	93/29/69
Location	9770 GOLDEN POND - CRESTON	Well #	
APN	070-182-027	Phone	SUE BYRD 235-3699

PUMP

Make				Model #			
H.P.	1	Serial #			Voltage	230	
Pipe size	1"	Type	350' SNAP & POP/ 20' SCH 120		Wire size	#12/#10	Type
Depth Setting	370'	Well Seal	5" X 1"		Check Valve		
Motor Date				Motor Model #			
Motor Serial #				Safety Rope	1/8" /3/8"		
Booster Pump Make				Model #			
Misc.							

## CONTROL

Control box _____	GP PUMPS _____	Make _____	1 HP _____
Pressure Switch _____	On _____	Lbs. _____	Off _____ Lbs.
Liquid Level _____	Low _____	High _____	
Relief Valve _____	Make _____	Setting _____	
Pump Panel Make _____	Voltage _____	Mag Size _____	
Heater/Overload _____	Fuses _____		
Misc. _____			

## STORAGE

Size \_\_\_\_\_ Galv ☐ Poly ☐ Fiberglass ☐  
 Pressure Tank Make \_\_\_\_\_ Size \_\_\_\_\_ Model \_\_\_\_\_  
 Misc. \_\_\_\_\_

WELL

Casing Size 5" Type PVC  
 Depth To Water 64.6' To Bottom 382'  
 G.P.M. @ Ft. Tested By \_\_\_\_\_  
 Misc. \_\_\_\_\_

**Abalone Coast Analytical, Inc.**

141 Suburban Rd, Ste C-1 San Luis Obispo CA, 93401

Phone: 595-1080 Fax: 595-1080

Order #: 17-3775

Date/Time Rec'd: 6/16/17 1344

**Filippi & Thompson Drilling**  
P.O. Box 845  
Atascadero, CA 93423

**Contact: Ned Thompson**  
Phone: 610-8237  
Sampler: Jerry Cook

Project:

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	9770 Golden Pond	6/15/17 1600	MPN Total Coliform	SM 9223 B.	ND.	MPN/100mL	1	06/17/17
	Creston, CA		MPN <i>E-coli</i>	IDEXX	ND.	MPN/100mL	1	06/17/17

This sample passes water quality standards for Total Coliform and E. Coli Bacteria.

Report Completion Date: 6/19/17

Reviewed By: Erika Frost

Erika Frost, Lab Director

**Definitions:**

MPN = Most Probable Number

State of California CDPH ELAP 2661

RL = Reporting Limit

ND = Analyte NOT DETECTED at or above MDL