

**NORTH STATE WATER TESTING****P.O. Box 1933****Chico, Ca 95927****Phone: (530) 345-3412****License NO: 9108**

---

**Well Water Production and Analysis Report****Date:** 6/8/17**Test Location:** 4266 Keefer Rd**Well Driller:** N/A**Depth of  
Well:** N/A**Date Drilled:** N/A**Well Size:** 8 INCH**Depth to Water:** N/A**Original  
G.P.M.:** N/A**Well Number:** 1**Of: (Wells)** 1**Type of Pump  
Used:** SUBMERSIBLE**Model  
Number:** 1.5 HP**G.P.M. Rate:** 12**Pumping System  
Supplied By:** FOLTZ CONSTRUCTION

**Start of Test:** Click or tap here to enter text.

Time:	Water Clarity:	G.P.M.:
12:00	Good	12
1:00	Good	12
1:30	Good	12
2:00	Good	12

**Reason For Stopping Test:** The 2 hour test was complete.

**Total Test Time:** 2 Hours

**G.P.M.:** 12

**Testing Operator:** Paul Behr

**Comments:** See attached system check documents.

NORTH STATE WATER TESTING IS PERFORMING THIS TEST TO PROVE MINIMUM CAPACITY OF THIS WELL, AND HEREBY CERTIFIES THAT THE ABOVE DATA IS CORRECT AND THAT DURING THE ENTIRE TESTING PERIOD, AN OPERATOR WAS PRESENT AND OPERATING THE EQUIPMENT NECESSARY FOR THIS TEST. NORTH STATE WATER TESTING MAKES NO CLAIM AS TO THE PERFORMANCE OR RELIABILITY OF THE ABOVE-NAMED WELL WATER SYSTEM.

Paul A. Behr Paul Behr

## Systems Check

### Pressure System

#### 1. Pressure Tank

<b>Type:</b>	BLADDER	<b>Size:</b>	85
<b>Operating Pressure:</b>	0-120	<b>Condition:</b>	GOOD

#### 2. Safety Relief Valve

<b>Location:</b>	WELLHEAD	<b>Condition:</b>	GOOD
------------------	----------	-------------------	------

#### 3. Check Valve:

<b>Location:</b>	WELLHEAD	<b>Condition:</b>	GOOD
------------------	----------	-------------------	------

#### 4. Schrader Valve:

<b>Location:</b>	NONE NEEDED	<b>Condition:</b>	-
------------------	-------------	-------------------	---

#### 5. Air Control

<b>Location:</b>	NONE NEEDED	<b>Condition:</b>	-
------------------	-------------	-------------------	---

#### 6. Vacuum Break:

<b>Location:</b>	NONE NEEDED	<b>Condition:</b>	-
------------------	-------------	-------------------	---

#### 7. Pressure Switch:

<b>Location:</b>	WELL HEAD	<b>Type:</b>	FURNAS
<b>P.S.I. On:</b>	35	<b>P.S.I. Off:</b>	55
<b>Condition:</b>	NEW		

**8. Leak Check:**

<b>Location:</b>	ALL TANK HOUSE LOCATIONS	<b>Results:</b>	NONE FOUND
------------------	--------------------------	-----------------	------------

**9. Piping Used:**

<b>Type:</b>	GALVANIZED	<b>Condition:</b>	GOOD
--------------	------------	-------------------	------

**10. Well Seal:**

<b>In Place:</b>	YES	<b>Type:</b>	PRESSURE EXPANSION
<b>Condition:</b>	GOOD		

**Weather Protection:****1. Tank House:**

<b>Location:</b>	NORTH WEST CORNER OF GARRAGE	<b>Type:</b>	CEMENT FLOOR, WOODEN STRUCTURE, GABLE ROOF SIMILAR TO DOG HOUSE
<b>Condition:</b>	GOOD		

**2. External Piping:**

<b>Protection Used:</b>	NONE	<b>Condition:</b>	-
-------------------------	------	-------------------	---

**Electrical System:****1. Service Disconnect:**

<b>Location:</b>	AT WELL	<b>Type:</b>	ON/OFF SWITCH
<b>Amps:</b>	30	<b>Condition:</b>	GOOD

**2. Wiring Service:**

<b>Conduit:</b>	UNDERGROUND	<b>Type:</b>	METAL FLEX. POLY FLEX, POLY PIPE
-----------------	-------------	--------------	-------------------------------------

**Condition:** GOOD

**3. Capacitor Unit:**

<b>Location:</b>	WELL HEAD	<b>Type:</b>	FRANKLIN ELECTRIC 1.5 HP
<b>Volts:</b>	220	<b>Condition:</b>	GOOD

**4. Load Test:**

<b>Amp Check:</b>	BLACK WIRE 7 AMP	<b>Heat Factor:</b>	NONE
<b>Performance:</b>	STANDARD		

**5. Main Panel:**

<b>Location:</b>	N/A	<b>Type:</b>	-
<b>Amps:</b>	-	<b>Condition:</b>	-

**Summary:**

PUMP SET AT 80 FEET IN 4/2004

# Paul Behr

---

Paul A. Behr  
North State Water Testing