



michael jones <jmjones.inc@gmail.com>

RE: Fire hydrant requirement for Parcel 13562, Parcel 2, 9785 Rim Rock Lane

Sibbet, David <David.Sibbet@sdcounty.ca.gov>

Thu, Feb 15, 2024 at 2:06 PM

To: michael jones <jmjones.inc@gmail.com>

Michael,

I received this below email from Roman at VCMWD, which shows that adding a fire hydrant as the covenant improvement requires. We will support adding a water tank as an alternative to a hydrant. The next step is including the tank on your building plans. Once the building plan is submitted, please contact me and include this email as a reminder) and I can write a letter releasing the covenant improvement.

Thanks

DAVID SIBBET, Fire Services Coordinator

SAN DIEGO COUNTY FIRE PROTECTION DISTRICT

Community Risk Reduction Division

(619) 672-7112

[5560 Overland Avenue, Suite 400](#)[San Diego, CA 92123-1234](#) MS O-302From: Roman De Manriquez <RDeManriquez@vcmwd.org>

Sent: Tuesday, February 6, 2024 11:38 AM

To: Sibbet, David <David.Sibbet@sdcounty.ca.gov>

Subject: [External] FW: Fire hydrant requirement for Parcel 13562, Parcel 2 9785 Rim Rock Lane

Mr. Sibbet,

A recent 8-inch water main extension VCMWD is accepting, has a total cost of \$204,000.00 (746 linear feet) pencils out @\$273 a linear foot.