

State License No. C57 432680
P.O. BOX 845
ATASCADERO, CA 93423
805-466-1271

PUMP INSTALLATION REPORT

Name HOWIE STEINBECK Date 3/1/2019
Address 5940 UNION ROAD PASO ROBLES, CA 93446 Code 63/34/20/69
Location 4950 UNION ROAD- PASO ROBLES Well # MOM'S Phone 805-674-1906

PUMP

Make GRUNDFOS Model # 300S750-18
H.P. 75 Serial # 14860018P118500001 Voltage 460 THREE PHASE
Pipe size 6" Type STEEL Wire size #1/0 Type JKT
Depth Setting 672' (12/8/16) Well Seal 16 X 6 Check Valve IN PUMP & half way
Motor Date H30182510009 Motor Model # P80A0750A4
Motor Serial # 338385902 Safety Rope N/A
Booster Pump Make Model #
Misc. 3/4" SOUNDER TUBE + 3/8 AIRLINE

CONTROL

Control box Make
Pressure Switch On Lbs. Off Lbs.
Liquid Level Low High
Relief Valve Make Setting
Pump Panel Make YASKAWA VFD Voltage 460V TRIPLE PHASE Mag Size
Heater/Overload Fuses

Storage

Size Galv ☐ Poly ☐ Fiberglass ☐
Pressure Tank Make Size Model
Misc.

WELL

Casing Size 10" w/ STEEL PROTECTOR Type PVC
Depth To Water 418' (3/1/19) To Bottom 929' (3/1/19)
G.P.M. @ Ft. Tested By



STATE LICENSE NO. C67 432680

P.O. Box 845

Atascadero, California 93423

(805) 466-1271

Name Harold Steinbeck

Address 5940 Mill Road- Paso Robles, CA 93446

Job Location 4950 Union Road- " Mom's Place" - Paso Robles

Well size 10"

Tested by C. Hall

Depth 940'

Rate of flow (gpm) 400

Date 1/24/2010

Phone 674-1906

Fax

Duration of test 12 hrs.+ recovery

Static level 360.5'

Well Test Report

Date	Time	Water level	G.P.M.
1/6/2010	5:30 AM	360.5	400
	5:35	386.9	400
	5:40	389.8	400
	5:45	391.9	400
	5:50	393.8	400
	6:00	396	400
	6:15	399.1	400
	6:30	403.3	390
	6:45	409	400
	7:00	411	400
	7:15	413.6	400
	7:30	415.9	400
	8:00	419.5	400
	8:30	422.3	400
	9:00	425.2	400
	9:30	427.5	400
	10:00	429.3	400
	10:30	431.7	400
	11:30	435.6	400
	12:30PM	439.5	400
	1:30	442.5	400
	2:30	445.5	400
	3:30	447	400
	4:30	449.9	400
	5:30	451.7	400

Recovery Test

Time	Water level
5:30PM	451.7
5:35	425.5
5:40	425.5
5:45	425.5
5:50	425.5
6:00	413.2
6:15	408.4
6:30	404.1
6:45	404.1
7:00	404.1
7:15	404.1
7:30	404.1

Additional Comments

Thank you,

Ned M. Thompson

Ned M. Thompson

Page 1 of 3

Owner's Well Number

Date Work Began 12/02/2009

Local Permit Agency San Luis Obispo County

Permit Number 2009-217

Permit Date 11/9/09

Well Completion Report

Refer to Instruction Pamphlet

No. e0100775

Date Work Ended 12/11/2009

DWR Use Only - Do Not Fill In

State Well Number/Site Number

Latitude

Longitude

APN/TRS/Other

Geologic Log

Orientation ☒ Vertical ☐ Horizontal ☐ Angle Specify

Drilling Method ROTARY

Drilling Fluid BENTONITE

Depth from Surface

Description

Describe material, grain size, color, etc

0	3	TOP SOIL
3	8	SAND & GRAVEL
8	94	SANDY BROWN CLAY
94	109	SAND & GRAVEL
109	124	BROWN CLAY
124	136	SAND & GRAVEL
136	156	BROWN CLAY
156	172	SAND & GRAVEL
172	205	BROWN CLAY
205	213	SAND & GRAVEL
213	223	BLUE CLAY
223	226	SAND & GRAVEL
226	240	BLUE CLAY
240	255	BROWN CLAY
255	259	SAND & GRAVEL
259	311	BROWN CLAY
311	325	SAND & GRAVEL
325	342	BROWN CLAY
342	346	SAND & GRAVEL
346	351	BROWN CLAY
351	354	SAND & GRAVEL
354	382	BROWN CLAY
382	386	SAND & GRAVEL
386	391	BROWN CLAY
391	396	SAND & GRAVEL
396	410	BROWN CLAY
410	422	SAND & GRAVEL
422	437	BROWN CLAY
437	462	SAND & GRAVEL
462	466	BROWN CLAY

Total Depth of Boring 980 Feet

Total Depth of Completed Well 940 Feet

Well Owner

Name Howard Steinbeck

Mailing Address 5940 Union Road

City Paso Robles State CA Zip 93446

Well Location

Address 4950 Union Road

City Paso Robles County San Luis Obispo

Latitude 35 38 70 N Longitude 120 36 47 W
Deg. Min. Sec. Deg. Min. Sec.

Datum Decimal Lat. Decimal Long.


APN Book 015 Page 053 Parcel 010

Township 26 S Range 13 E Section 29

Location Sketch

(Sketch must be drawn by hand after form is printed.)

North



Illustrate or describe distance of well from roads, buildings, fences, rivers, etc. and attach a map. Use additional paper if necessary. Please be accurate and complete.

Activity

- ☒ New Well
☐ Modification/Repair
☐ Deepen
☐ Other
☐ Destroy

Describe procedures and materials under "GEOLOGIC LOG"

Planned Uses

- ☒ Water Supply
☐ Domestic ☐ Public
☒ Irrigation ☐ Industrial
☐ Cathodic Protection
☐ Dewatering
☐ Heat Exchange
☐ Injection
☐ Monitoring
☐ Remediation
☐ Sparging
☐ Test Well
☐ Vapor Extraction
☐ Other

Water Level and Yield of Completed Well

Depth to first water (Feet below surface)

Depth to Static

Water Level 340 (Feet) Date Measured 12/11/2009

Estimated Yield * 1,000 (GPM) Test Type Air Lift

Test Length 1.0 (Hours) Total Drawdown (Feet)

*May not be representative of a well's long term yield.

Casings

Depth from Surface Feet to Feet	Borehole Diameter (Inches)	Type	Material	Wall Thickness (Inches)	Outside Diameter (Inches)	Screen Type	Slot Size if Any (Inches)
0	440	19	BLANK	PVC	SDR 21	10	
440	540	19	SCREEN	PVC	SDR 21	10	0.040
540	560	19	BLANK	PVC	SDR 21	10	
560	660	19	SCREEN	PVC	SDR 21	10	0.040
660	680	19	BLANK	PVC	SDR 21	10	
680	940	19	SCREEN	PVC	SDR 21	10	0.040

Annular Material

Depth from Surface Feet to Feet	Fill	Description
0	51	CEMENT
51	940	FILL LAPIS #3 SAND

Attachments

- ☐ Geologic Log
☐ Well Construction Diagram
☐ Geophysical Log(s)
☐ Soil/Water Chemical Analyses
☐ Other

Attach additional information, if it exists.

Certification Statement

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief
Name Filipponi & Thompson Drilling, Inc.

Person, Firm or Corporation

P.O. Box 845

Atascadero

CA 93423

Signed

Address

City

State

Zip

C-57 Licensed Water Well Contractor

Date Signed 12/14/09

432680

C-57 License Number

File Original with DWR

Page 2 of 3

Owner's Well Number _____

Date Work Began 12/02/2009

Date Work Ended 12/11/2009

Local Permit Agency San Luis Obispo County

Permit Number 2009-217

Permit Date 11/9/09

Well Completion Report

State of California

Refer to Instruction Pamphlet

No. **e0100775**

DWR Use Only - Do Not Fill In	
State Well Number/Site Number	
Latitude	Longitude
APN/TRS/Other	

Geologic Log

Orientation ☒ Vertical ☐ Horizontal ☐ Angle Specify _____
Drilling Method ROTARY Drilling Fluid BENTONITE

Depth from Surface Feet to Feet Description Describe material, grain size, color, etc

466	472	SAND & GRAVEL
472	476	BROWN CLAY
476	510	SAND & GRAVEL
510	522	SANDY BROWN CLAY
522	546	SAND & GRAVEL
546	557	SANDY BROWN CLAY
557	565	SAND & GRAVEL
565	574	BROWN CLAY
574	613	SAND & GRAVEL
613	616	BROWN CLAY
616	624	SAND & GRAVEL
624	626	BROWN CLAY
626	644	SAND & GRAVEL
644	680	BROWN CLAY
680	686	SAND & GRAVEL
686	690	BROWN CLAY
690	702	SAND & GRAVEL
702	711	BROWN CLAY
711	716	BROWN SAND
716	721	BROWN CLAY
721	724	SAND & GRAVEL
724	737	SANDY BROWN CLAY
737	750	SAND & GRAVEL
750	753	BROWN CLAY
753	780	SAND & GRAVEL
780	785	BROWN CLAY
785	787	SAND & GRAVEL
787	799	BROWN CLAY
799	820	SAND & GRAVEL
820	826	BROWN CLAY

Total Depth of Boring 980 Feet

Total Depth of Completed Well 940 Feet

Well Owner

Name Howard Steinbeck

Mailing Address 5940 Union Road

City Paso Robles State CA Zip 93446

Well Location

Address 4950 Union Road

City Paso Robles County San Luis Obispo

Latitude 35 38 70 N Longitude 120 36 47 W
Deg. Min. Sec. Deg. Min. Sec.

Datum _____ Decimal Lat. _____ Decimal Long. _____


APN Book 015 Page 053 Parcel 010

Township 26 S Range 13 E Section 29

Location Sketch

(Sketch must be drawn by hand after form is printed.)

North



Illustrate or describe distance of well from roads, buildings, fences, rivers, etc. and attach a map. Use additional paper if necessary. Please be accurate and complete.

Activity

- ☒ New Well
☐ Modification/Repair
☐ Deepen
☐ Other _____
☐ Destroy
Describe procedures and materials under "GEOLOGIC LOG"

Planned Uses

- ☒ Water Supply
☐ Domestic ☐ Public
☒ Irrigation ☐ Industrial
☐ Cathodic Protection
☐ Dewatering
☐ Heat Exchange
☐ Injection
☐ Monitoring
☐ Remediation
☐ Sparging
☐ Test Well
☐ Vapor Extraction
☐ Other _____

Water Level and Yield of Completed Well

Depth to first water _____ (Feet below surface)

Depth to Static _____

Water Level 340 (Feet) Date Measured 12/11/2009

Estimated Yield * 1,000 (GPM) Test Type Air Lift

Test Length 1.0 (Hours) Total Drawdown _____ (Feet)

*May not be representative of a well's long term yield.

Casings

Depth from Surface Feet to Feet	Borehole Diameter (Inches)	Type	Material	Wall Thickness (Inches)	Outside Diameter (Inches)	Screen Type	Slot Size If Any (Inches)
0	440	19	BLANK	PVC	SDR 21	10	
440	540	19	SCREEN	PVC	SDR 21	10	0.040
540	560	19	BLANK	PVC	SDR 21	10	
560	660	19	SCREEN	PVC	SDR 21	10	0.040
660	680	19	BLANK	PVC	SDR 21	10	
680	940	19	SCREEN	PVC	SDR 21	10	0.040

Annular Material

Depth from Surface Feet to Feet	Fill	Description
0	51	CEMENT
51	940	FILL LAPIS #3 SAND

Attachments

- ☐ Geologic Log
☐ Well Construction Diagram
☐ Geophysical Log(s)
☐ Soil/Water Chemical Analyses
☐ Other _____

Attach additional information, if it exists.

Certification Statement

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief
Name Filipponi & Thompson Drilling, Inc.

Person, Firm or Corporation

P.O. Box 845

Address Atascadero

City CA 93423

Signed _____

City

State

Zip

C-57 Licensed Water Well Contractor

Date Signed 12/14/09

432680 C-57 License Number

File Original with DWR

State of California

Well Completion Report

Refer to Instruction Pamphlet

No. e0100775

Page 3 of 3

Owner's Well Number

Date Work Began 12/02/2009

Date Work Ended 12/11/2009

Local Permit Agency San Luis Obispo County

Permit Number 2009-217

Permit Date 11/9/09

DWR Use Only - Do Not Fill In

State Well Number/Site Number

Latitude

Longitude

APN/TRS/Other

Geologic Log

Orientation ☒ Vertical

☐ Horizontal

☐ Angle Specify

Drilling Method ROTARY

Drilling Fluid BENTONITE

Depth from Surface

Description

Feet to Feet

Describe material, grain size, color, etc

826 840 SAND & GRAVEL

840 845 BROWN CLAY

845 850 SAND & GRAVEL

850 878 BROWN CLAY

878 880 SAND & GRAVEL

880 900 BROWN CLAY

900 907 SAND & GRAVEL

907 916 BLUE CLAY

916 930 SAND & GRAVEL

930 948 BLUE CLAY

948 950 SAND & GRAVEL

950 953 BLUE CLAY

953 956 SAND & GRAVEL

956 960 BROWN CLAY

960 980 DARK GREY CLAY

The Air Lift Test is only approximate. A Test Pump is recommended for an accurate account. (WP)

Total Depth of Boring 980 Feet

Total Depth of Completed Well 940 Feet

Well Owner

Name Howard Steinbeck

Mailing Address 5940 Union Road

City Paso Robles

State CA

Zip 93446

Well Location

Address 4950 Union Road

City Paso Robles

County San Luis Obispo

Latitude 35 38 7.0 N Longitude 120 36 47 W

Datum Decimal Lat. Decimal Long.

APN Book 015 Page 053 Parcel 010

Township 26 S Range 13 E Section 29

Location Sketch

(Sketch must be drawn by hand after form is printed.)

North

West

East

South

Illustrate or describe distance of well from roads, buildings, fences, rivers, etc. and attach a map. Use additional paper if necessary. Please be accurate and complete.

Activity

- ☒ New Well
☐ Modification/Repair
☐ Deepen
☐ Other
☐ Destroy

Describe procedures and materials under "GEOLOGIC LOG"

Planned Uses

- ☒ Water Supply
☐ Domestic ☐ Public
☒ Irrigation ☐ Industrial
☐ Cathodic Protection
☐ Dewatering
☐ Heat Exchange
☐ Injection
☐ Monitoring
☐ Remediation
☐ Sparging
☐ Test Well
☐ Vapor Extraction
☐ Other

Water Level and Yield of Completed Well

Depth to first water (Feet below surface)

Depth to Static

Water Level 340 (Feet) Date Measured 12/11/2009

Estimated Yield * 1,000 (GPM) Test Type Air Lift

Test Length 1.0 (Hours) Total Drawdown (Feet)

*May not be representative of a well's long term yield.

Casings

Depth from Surface Feet to Feet	Borehole Diameter (Inches)	Type	Material	Wall Thickness (Inches)	Outside Diameter (Inches)	Screen Type	Slot Size If Any (Inches)
0 440	19	BLANK	PVC	SDR 21	10		
440 540	19	SCREEN	PVC	SDR 21	10		0.040
540 560	19	BLANK	PVC	SDR 21	10		
560 660	19	SCREEN	PVC	SDR 21	10		0.040
660 680	19	BLANK	PVC	SDR 21	10		
680 940	19	SCREEN	PVC	SDR 21	10		0.040

Annular Material

Depth from Surface Feet to Feet	Fill	Description
0 51	CEMENT	
51 940	FILL	LAPIS #3 SAND

Attachments

- ☐ Geologic Log
☐ Well Construction Diagram
☐ Geophysical Log(s)
☐ Soil/Water Chemical Analyses
☐ Other

Attach additional information, if it exists.

Certification Statement

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief

Name Filipponi & Thompson Drilling, Inc.

Person, Firm or Corporation

P.O. Box 845

Atascadero

CA

93423

Signed

Address

City

State

Zip

C-57 Licensed Water Well Contractor

Date Signed 12/14/09

432680

C-57 License Number