

Abalone Coast Analytical, Inc.
141 Suburban Rd, Ste C-1 San Luis Obispo CA, 93401
Phone: 595-1080 Fax: 595-1075

Order #: 24-3409
Date/Time Rec'd: 8/7/24 1509

Farm Supply Company
224 Tank Farm Road
San Luis Obispo, CA 93401


Contact: Josh Ianneo
Phone: 530-809-5699
Sampler: Abel Garcia

Project: 4410 Upper Lopez Canyon PO# 47719001

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	4410 Upper Lopez	8/7/24 1300	Total Coliform	SM 9223 B.	Absent	/100ml	1	08/08/24
	Canyon		<i>E-coli</i>	IDEXX	Absent	/100ml	1	08/08/24

This sample passes water quality standards for Total Coliform and E. Coli Bacteria.

Report Completion Date: 8/8/24

Reviewed By: 
Priyanka Singh, Technical Director

Definitions:

Absent = Less than 1 CFU/100mLs

State of California CDPH ELAP 2661

Present = 1 or more CFU/100mLs

CFU = Colony Forming Unit

RL = Reporting Limit

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.