

State License No. C57 432680
 P.O. BOX 845
 ATASCADERO, CA 93423
 805-466-1271

PUMP INSTALLATION REPORT

Name RANDY PARTIN Date 7/29/2004
 Address 9165 Harvest Way Atascadero, CA 93446 Code 63
 Location 9165 Harvest Way Atascadero Well # 1 Phone 805-975-7732

PUMP

Make Sta-Rite Model # 10P4E02J-04
 H.P. 1 Serial # 1E04U Voltage 230 Single Phase
 Pipe size 1" Type PVC SCH 80 T&C Wire size 14/4 Type Jkt
 Depth Setting 160' Well Seal 5x1 Check Valve Above Pump
 Motor Date 03L18 19-2619 Motor Model # 2145089003
 Motor Serial # 337453915 Safety Rope 3/8"
 Booster Pump Make Goulds (10/8/13) Model # 2 HP HSC20
 Misc.

CONTROL


Control box 1 Hp Make Franklin
 Pressure Switch Square D FSG-2 (4/29/19) On 50 Lbs. Off 70 Lbs.
 Liquid Level Low High
 Relief Valve 3/4" Make Watts Setting 75#
 Pump Panel Make Voltage Mag Size
 Heater/Overload Fuses

Storage

Size 5000 Galv Poly Fiberglass
 Pressure Tank Make Pro Line (1/09/06) Size 86 Gallon Model
 Pressure Tank Make Pro Line (10/10/07) Size 86 Gallon Model
 Misc.

WELL

Casing Size 5" Type PVC
 Depth To Water 39.5 (3/1/23) To Bottom 500' WCR#E008945 (10/3/03)
 G.P.M. 12 @ 97 Ft. Tested By M. BOLLINGER



State License No. C57 432680
 P.O. BOX 845
 ATASCADERO, CA 93423
 805-466-1271

Name RANDY PARTIN
 Mailing Address 9165 HARVEST WAY, ATASCADERO, CA 93423
 Job Location 9165 HARVEST WAY, ATASCADERO, CA 93423
 Well Size 5" Depth 500'
 Tested by M. BOLLINGER Rate of Flow (gpm) 12

Date 3/3/2023
 Phone 805-441-6883
 APN 070-110-014
 Duration 4 HR + RECOVERY
 Static Level 39.5

Well Test Report

<u>Date</u>	<u>Time</u>	<u>Water Level (FT)</u>	<u>G.P.M.</u>	<u>Drawdown</u>
3/1/2023	8:00AM	39.5	14.0	
	8:05	55.7	13.0	-16.2
	8:10	66.9	13.0	-27.4
	8:20	75.7	12.5	-36.2
	8:30	80.8	12.5	-41.3
	8:40	83.3	12.5	-43.8
	8:50	84.9	12.5	-45.4
	9:00	86.5	12.5	-47.0
	9:20	88.9	12.0	-49.4
	9:40	90.1	12.0	-50.6
	10:00	91.9	12.0	-52.4
	10:20	92.8	12.0	-53.3
	10:40	93.8	12.0	-54.3
	11:00	94.5	12.0	-55.0
	11:20	95.4	12.0	-55.9
	11:40	96.2	12.0	-56.7
	12:00PM	96.8	12.0	-57.3

Recovery

<u>Date</u>	<u>Time</u>	<u>Water Level (FT)</u>
3/1/2023	12:05PM	72.9
	12:10	65.3
	12:15	58.7

Additional Comments:
 PUMP WAS SET AT 160'

Thank you,

Ned M. Thompson

Abalone Coast Analytical, Inc.

141 Suburban Rd, Ste C-1 San Luis Obispo CA, 93401
Phone: 595-1080 Fax: 595-1075

Order #: 23-1089
Date/Time Rec'd: 3/2/23 1147

Filippini & Thompson Drilling
P.O. Box 845
Atascadero, CA 93423

Contact: Ned Thompson
Phone: 805-466-1271
Sampler: Marc Bollinger

Project: **Partin**

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-1	9165 Harvest Way	3/1/23 1150	MPN Total Coliform	SM 9223 B.	ND.	MPN/100mL	1	03/03/23
			MPN E-coli	IDEXX	ND.	MPN/100mL	1	03/03/23

This sample passes water quality standards for Total Coliform and E. Coli Bacteria.

Report Completion Date: _____

3/3/23

Reviewed By: _____



Priyanka Singh, Technical Director

Definitions:

MPN = Most Probable Number

State of California CDPH ELAP 2661

RL = Reporting Limit

ND = Analyte NOT DETECTED at or above MDL

Coliform are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of Fecal coliforms and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.