

MOUNTAIN HYDRO

77 E. So. El Pomer
Templaton, Ca. 93485
(805) 434-1944
Lic. No. 164030

PUMP TEST REPORT

Well Owner Bart/Mc DONALD

Pump Size 1 hp Well # 1

Well Address 80 Acer Copper Head

Pump Size 1 hp Well Depth 400?

Testing Method Sub Pump

Property Lake Country Property

Pert Rec UNKNOWN

Standing Level Before Testing 24.7

APN Location 422-231-010

TIME	WATER CONDITION	PUMPING LEVEL	GPM
12:45	clear	24.7	START
12:46 1 min	clear / slightly sandy	37.7	12
12:47 2 min	" "	47.6	12
12:48 3 min	" "	57.2	12
12:49 4 min	" "	65.3	12
12:50 5 min	" "	71.65	12
1:00 15 min	" "	82.9	12
1:10 25 min	" "	95.7	12
1:30 45 min	" "	101.5	12
1:45 1 hr	" "	108.2	12
2:00	" "	118.0	12
2:30	" "	125.7	12
3:00	" "	127.5	12
3:30	" "	139.2	12
4:00	" "	142.1	12
4:30	" "	145.4	12
4:45	" "	148.3	12
END	" "		
	" "		
	" "		
	" "		
5:00	Recovery	32.4	0

Notes: Well produced 12 GPM For 4 hours, some very light
SAND was noted in collection Bucket.

Standing Level After Testing 32.4

FINAL TEST RESULTS Produced 12 GPM for 4 hours on (date) 3-2-2000

Test Run By Greg Bailey