TOWN OF PARADISE
ONSITE WASTEWATER MANAGEMENT ZONE
EVALUATION REPORT

Permit Number: OS21-02308
AP Number: 050-180-095-000
Property Address: 6639 CREEKSIDE DR
Occupancy Type: Single Family

Primary Contact: REQUESTED BY REAL ESTATE PROFESSIONALS
C/O BARBARA TORRES @ REP; BWT/PG
PARADISE, CA 95969

Evaluation Date: 06/23/2021

Evaluator: MARK MUHLBAIER
PARADISE SANITATION CO

Evaluation Results

Pump Only	No	
Access Risers in Place	No	
Sanitary Tee - Inlet	Yes	
Scum Depth, Inlet Compartment	0	Inches
Sludge Depth, Inlet Compartment	0	Inches
Structural Tank Condition	Good	
Liquid from Operating Level	Normal	
Baffle Condition	Good	
Tank Volume	1000	Gallons
Sanitary Tee - Outlet	Yes	
Scum Depth, Outlet Compartment	0	Inches
Sludge Depth, Outlet Compartment	0	Inches
Tank Material	Concrete	
Septic Tank Pumping Required	No	
Was Septic Tank Pumped	No	
Depth to Septic Tank Access Lid - Inlet	10	Inches
Depth to Septic Tank Access Lid - Oulet	10	Inches
Effluent Pump	No	
Effluent Line Diverter Valve	No	
Well on Property	No	
Common Area/Community Absorption Field	No	
Absorption Field Type	Standard	
Surfacing Effluent	No	
Hydraulic Load Test	Yes	
Hydraulic Load Test - Results	Good	
Down Slope Seepage	No	
Saturated Absorption Field	No	
Multiple Systems	No	
Graywater Discharge	No	

Evaluator Comments

Tank inspected post Camp Fire, appears to be structurally sound and operating at normal liquid level. Water truked in for HLT, absorption field tested Good

Location Sketch

