



Downey Plumbing, Heating & Air Conditioning Co.,
 Inc. ~ State License 731172
 11829 Downey Avenue
 Downey, CA 90241

Date Created: 07/10/2023 4:42 PM

WORK ORDER **WO-0035623**

Client

Name: Home Serve USA Repair Mgmt Corp **Contact:** Property Management
Service Location Address: Contractor Support Dept.
 Contractor Support Dept. 1232 Premier Dr.,
 Ste. #100
 Chattanooga, TN 37421
Billing Address: Billing address is same as Service Location address.

Problem

Stoppages Mainline w/cleanout Done
 J B Owens Jr
 2640 VIA RIVERA
 Palos Verdes Estates CA, 90274
 POC: Jackie 805-895-7873
 or
 Cindy 714-655-3314
 Job#SHMR73713D90-1
 Issue: S-Exterior Sewer/Septic Line
 slow to drain, cleanout in backyard

Work Done

Repair Category: Plumbing
Repair Code: Plumbing
Description: Location: J B Owens Jr 2640 VIA RIVERA, Palos Verdes Estates CA, 90274
 On site for mainline stoppage. Ran mainline approximately 95 feet to clear stoppage through exterior clean out. Pulled back medium size roots . Ran the mainline again and no roots where pulled the second time . Tested and mainline was flowing .
 Enroute:11:57am Started:12:21pm Finished:12:48pm

Time Recorded

Started: 12:42 PM 07/13/23
 Completed: 12:47 PM 07/13/23
Total Time: 0h : 05m

Signatures

Work Accepted by: _____ **Date:** _____

Completed by: _____ **Date:** _____