

PRECISION SEPTIC, INC.

A-GENERAL ENGINEERING CONTRACTOR, LIC #: 867126

Bill Bowman: (805) 859-4885

4200 Potrero Rd, Atascadero, CA 93422

Inspection-Certification of Septic System

Inspection Date: 2-10-26 Inspection Address: 1225 SANTA RITA Rd

TEMPLETON, CA

Property Owner: _____

Realtor/Finance Company: JY CHRISTENSEN Title Company: _____

Inspection Specifics

Septic tank size: 1200 Septic tank construction: CONCRETE

Tank liquid level: HIGH Internal piping conditions: PASS

Effluent filter present: NO Access lids: PASS - 30" COVER & INSPECTION PORT

Gravity or Pump system: _____ Condition of tank: PASS

Septic tank pumped during inspection: YES

Operational leach field 30 minute water test: FAIL

Wells, natural water ways, or setback issues present: WELL 200'

Comments: _____

_____ At the time of this inspection the septic system appears to be in good working order
and can be expected to function correctly with proper maintenance.

At this time the septic system is NOT in good working order and will NOT
function properly without the following repairs:

Inspector Blm

- The results of this inspection in no way guarantee future function of the septic system or its components. Future functionality will depend on Proper Usage, Environment, and Maintenance.
- This inspection is good for 90 days.

PRECISION SEPTIC, INC.

A-GENERAL ENGINEERING CONTRACTOR, LIC #: 867126

Bill Bowman: (805) 859-4885


4200 Potrero Rd, Atascadero, CA 93422

Septic System Approximate Plan

Date: 2-10-26

Address: 1225 SANTA RITA Rd.

Comments:



Drawing not to scale. Locations are approximate.