

COUNTY OF LOS ANGELES FIRE DEPARTMENT

JURISDICTION/SHIFT 83

OFFICIAL INSPECTION REPORT 1320 N. EASTERN AVENUE, LOS ANGELES, CALIFORNIA 90063-3294

			Pos		Door Hanger	☐ To Occupant	
ADDR	ESS 30695 Ganado Drive			DATE_	7/12/21		
OWNER'S NAME		OCCUPANT NAME		PHONE			
TYPE OF OCCUPANCY		TYPE OF CONSTRUCTION ROOF TYPE					
		PARCEL NO: 7558	/ 011 / 007	_			
\$894 EXPE	ADDRESSED PROPERTY IS IN VIOLATION IN THE CONTROL OF T	OR BEFOREAND POSSIBLE LEGAL ACTION		MPLY MAY F HE COUNTY	RESULT IN A \$50 MAY CLEAR I	00 ADMINISTRATIVE FINE, PROPERTY AT OWNER'S	
□1.	Clearance of Brush and Combustible G	rowth:					
	A. Establish a 5 foot Ember Resistant Zone around all structures. Eliminate vegetation and materials that could be ignited by embers from a wildfire.						
0	B. Clear and remove all flammable vegetation or combustible growth located 30 feet around any structure or, 50 feet around any structure in extra hazard areas. This includes ornamental plants and trees known to be flammable, including, but not limited to: Acacia, Cedar, Cypress, Eucalyptus, Juniper, Pine and Pampas Grass. Exception: Ornamental plants and trees that are individually planted, or cultivated ground cover such as green grass, succulents, or similar plants, spaced and maintained in such a manner that they do not form a means of transmitting fire from native growth to the structure (F.C. 325.2.1(2), 325.2.2).						
	C. Clear, cut back, thin out, trim up and remove flammable vegetation or combustible growth for a distance of 100 feet around any structure or, 200 feet around any structure in extra hazard areas so as to create a firebreak. This section shall not apply to single specimens of either native or ornamental trees, shrubs or ground covers provided they are cut back, thinned out, trimmed up and spaced so as to provide an adequate firebreak and do not form a fuel ladder to any structure (F.C. 325.2.1(2)(3), 325.2.2).						
	D. Roadways: The fire code official or commissioner may require removal and clearance of all flammable or other combustible growth for a minimum of 10 feet on each side of every roadway whether public or private (F.C. 325.10).						
□ 2.	Trees overhanging fire access roads shall be maintained to provide vertical clearance. (F.C. 503.2.1)						
□3.							
□ 4. □ -							
□ 5.							
□ 6.	Combustible Materials: Place or store find (F.C. 325.2.1(1)).	rewood, manure, compost or othe	r combustible materials	a minimum o	if thirty (30) feet f	rom any building or structure	
□7.	Tents: When a tent or membrane structu structures or from areas within up to 200 to						
□8.	LP Gas Storage Tanks: Weeds, grass, "No Smoking" signs complying with Section			•		LP-gas tanks or containers.	
Cleara		lations Found Per DSI	•	,	,		
					•		
□9.	Spark Arrestor Required: Each chimney used in conjunction with any fireplace, barbecue, incinerator, or any heating appliance in which solid or liquid fuel is used, upon any building, structure, or premises located within any hazardous fire area, shall be maintained with a spark arrestor constructed of a heavy wire mesh or other noncombustible material with opening not to exceed one-half inch (F.C. 326.12.2).						
□ 10.	Illegal Dumping: No person shall place, deposit, or dump any garbage, cans, bottles, papers, ashes, refuse, trash, rubbish, or combustible waste material in or upon any hazardous fire area. No person shall dump such material in, upon, or along any trail, roadway or highway in a hazardous area (F.C. 326.15).						
□ ₁₁ .	Fire Department Key System: Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving of firefighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official. An approved lock shall be installed on gates or similar barriers where required by the fire code official (F.C.506.1, 506.1.1).						
□ _{12.}	Building Address Numbers: New and e a position that is plainly legible and visi numbers shall be Arabic numerals or alph	ble from the street or road fronti	ng the property. Thes	se numbers s	hall contrast with	their background. Address	
□ _{13.}	Fire apparatus access roads: shall be p	rovided and maintained in accorda	nce with Fire Code Sect	tions 503.1.1	through 503.6.		
	aproper and illegal for any County officer, eations include requests for anything of value						
Any at	ttempt by a County employee to solicit bribyising the employee or the Fraud Hotline at	es, gifts or gratuities for any reas	on should be reported in aud.org. YOU MAY REM	mmediately to	o either the Coun		
INSPI	ECTORSignature			or Moore		_	
FOR	INFORMATION CALL ()						
	,,						
Poste	· ·	•	NC C (2)		NC	C	
	spection Dates: (1)	NC C (2)	<u> </u>		NC_	<u>u</u>	
Signa	ture					_	
Name	•						

BRUSH CLEARANCE REQUIREMENTS

Thousands of homes are in serious danger of destruction by fire because of their proximity to brush-covered areas. Homes with wood shake roofs, wood siding, decks, patio covers or exposed eaves are particularly vulnerable to the spread of fire. Despite efforts by firefighters, wildland fires fanned by strong winds can destroy homes. It is your legal responsibility to take the necessary actions to clear vegetation around any given structures. A firesafe landscape creates a defensible space to help protect against approaching wildfires.

- 1. All flammable vegetation identified as a fire hazard by the inspecting officer shall be mowed or cut to a stubble height of 3 inches, for 30 feet around any structure or 50 feet in high hazard areas.
- 2. Thin remaining vegetation for the next 70 feet, for a total of 100 feet, around any structure by clearing, trimming, thinning, limbing up, and removing flammable and dead vegetation. For high hazard areas, this distance can be increased to a maximum of 200 feet.
- 3. Specimen native trees and shrubs are permissible, provided that they do not form a means of transmitting fire to any structure. Specimens should be spaced with a minimum of 15 to 30 feet from the edge of the canopy to surrounding native brush and trees, depending on the slope and height of the individual plants, and far enough away so that they don't touch or overhang structures. Typical spacing of smaller brush and shrubs should be 3 times their height from specimens or other groups of plants, from edge to edge, up to a distance of 15 feet.
- 4. All trees and shrubs shall be maintained free of dead wood and litter. Shrubs shall be trimmed up from the ground 1/3 of their height. Trees shall be trimmed up a minimum of 6 feet or 1/3 their height up to 40 feet, depending on surface fuels.
- 5. Access roads shall be maintained with a minimum of 10 feet brush clearance on each side. Trees and shrubs shall be trimmed to provide vertical clearance over roadways.
- 6. Provide a minimum 3 feet clearance around all fire hydrants.

All plants will burn under extreme fire weather conditions. Fire resistant plants burn at a relatively low intensity when maintained. To best protect your home from fire, it is recommended that fire resistant plants are used when landscaping. A list of these plants can be obtained through the Los Angeles County Fire Department, Brush Clearance Unit, telephone number: (626) 969 - 2375

BRUSH CLEARANCE MAINTENANCE IS A YEAR-ROUND RESPONSIBILITY

REMEMBER: EXTRA HAZARDOUS AREAS MAY REQUIRE 200 FEET OF CLEARANCE

NOTE: Care should be taken when reducing the amount of fuel cover on slopes so as not to create an erosion problem.

