

Lic#1009043

PO BOX 3357 PASO ROBLES CA 93447 805-221-5493

Inspection/Certification

Date of Inspection: 2/5/25 Property Owner: Casa Medical Marketing LLC

Inspection Address: 390 San Marcos Rd, Paso Robles Ca 93446

Realtor/Finance Company: Clint Kuhnle

Title Company: N/A

I examined the existing septic system at the location above and determined:

Septic tank capacity: 1500

Septic tank construction: Concrete

Liquid level in tank: Good

Condition of tank: Good

Effluent filter present: No

Condition of access lids: Good

Septic tank pumped during inspection: Yes

Back flow from leach field before or after pumping septic tank: No

Operational leach field 30-minute water test: Passed

Setback issues from dwellings, wells, or natural water courses: None

Evidence of surfacing effluent found on property: No

Comments: The septic tank should be serviced every 3-5 years.

X: It is my opinion that, as of now, the septic system appears to be in good working order and can be expected to function correctly with proper maintenance. No repairs are needed at this time.

: It is my opinion that, as of now, the septic system is NOT in good working order and will NOT function properly without the following repairs:

Brian Padgett - Alliance Septic Service

- * The results of this inspection in no way guarantee future function of the septic system or its components. Future functionality will depend on proper usage, environment, and maintenance.
- * This inspection is good for 90 days.
- *Color and texture of soil may look different upon completion over excavated/graded areas.
- * Sewer pipes from the building(s) to the wastewater system, and greywater diversions of any kind are not included in this inspection.
- *Soil color and texture may look different upon completion of work. Rocks/boulders may be visible at ground surface.



Date: 2/25/25 Address: 340 San Marces Rd Pasa Comments: 1500 gel conc. tunh Depth From Top of Tank to Grade P:265:16 y Full Diameter Access Risers to Grade Clean Out Present _______ Distance to wellhead 100+1 Horse

Locations shown are approximate. Exact locations and scales are not within the scope of this inspection





Lic#1009043

PO BOX 3357 PASO ROBLES CA 93447 805-221-5493

Inspection/Certification

Date of Inspection: 2/5/25 Property Owner: Casa Medical Marketing LLC

Inspection Address: 380 San Marcos Rd, Paso Robles Ca 93446

Realtor/Finance Company: Clint Kuhnle

Title Company: N/A

I examined the existing septic system at the location above and determined:

Septic tank capacity: 1200

Septic tank construction: Concrete

Liquid level in tank: Good

Condition of tank: Good

Effluent filter present: No

Septic tank construction: Concrete

Gravity/Pump system: Gravity

Condition of internal piping: Good

Condition of access lids: Good

Septic tank pumped during inspection: Yes

Back flow from leach field before or after pumping septic tank: No

Operational leach field 30-minute water test: Passed

Setback issues from dwellings, wells, or natural water courses: None

Evidence of surfacing effluent found on property: No

Comments: The septic tank has a large number of roots in both the primary and secondary chambers. The septic tank sludge was unable to be cleaned out in its entirety due to the roots. Will need to pump the tank again to remove the roots and get the remaining sludge removed.

: It is my opinion that, as of now, the septic system appears to be in good working order and can be expected to function correctly with proper maintenance. No repairs are needed at this time.

X: It is my opinion that, as of now, the septic system is NOT in good working order and will NOT function properly without the following repairs: Remove roots and re-pump septic tank to remove the remaining sludge. (See attached proposal)


Brian Padgett - Alliance Septic Service

- * The results of this inspection in no way guarantee future function of the septic system or its components. Future functionality will depend on proper usage, environment, and maintenance.
- * This inspection is good for 90 days.
- *Color and texture of soil may look different upon completion over excavated/graded areas.
- * Sewer pipes from the building(s) to the wastewater system, and greywater diversions of any kind are not included in this inspection.
- *Soil color and texture may look different upon completion of work. Rocks/boulders may be visible at ground surface.



Date:				
Address: , 380 San Muses Rel Plase				
Comments: 120 god Conc tanh w/ Primary Lid 6" below				
gull_				
Full Diameter Access Risers to Grade Depth From Top of Tank to Grade 18 '				
Distance to wellhead 100 4 Clean Out Present				
House				
) March				
Server 18.				
N 18.				
,				
pere 1				
Port Stope				
V				

Locations shown are approximate. Exact locations and scales are not within the scope of this inspection





Lic#1009043

PO BOX 3357 PASO ROBLES CA 93447 805-221-5493 PROPOSAL

Customer: Casa Medical Marketing LLC

380 San Marcos Rd Paso Robles Ca 93446

Job Site: Same

<u>Proposal Date:</u> 2/11/25 <u>Work Start/End Date:</u> TBD


Work Description: Re-pump tank and remove roots.

- 1. Pump tank down to allow tank entry.
- 2. Perform tank entry into both chambers using all necessary safety gear; tri pod, winch, fresh air blower, and H2S gas meter.
- 3. Remove as many roots as possible from the septic tank. Haul away and dispose.
- 4. Re-pump the septic tank in its entirety to remove remaining sludge that was unable to be pumped during the initial inspection.
- 5. Backfill, compact, and rough grade area.

Total Cost: \$1,445.00

- *Payment is due at time of service/upon completion, unless billed to an approved escrow account.
- *This proposal is good for 30 days.
- *Color and texture of soil may look different upon completion over excavated/graded areas.
- *Alliance Septic is not responsible for unmarked utilities, including sprinkler lines.
- *We will backfill and compact over excavated areas, but cannot guarantee against future settling over deep excavations.

Customer Signature	Date
Customer Print	



Invoice

Date	Invoice #
2/11/2025	6923

Due Upon Receipt

Ronald McGee-Casa Medical Marketing Loss 380 San Marcos Rd
Paso Robles Ca 93446

Ρ.	Ο.	No.

Project

Quantity	Description	Rate	Amount
1	Escrow inspection on a 1200-gallon septic system - 380 San	200.00	200.00
	Marcos Rd, Paso Robles		
	Pump septic tank (up to 1200-gallons)	595.00	595.00
1	Escrow inspection on a 1500-gallon septic system - 390 San	200.00	200.00
	Marcos Rd, Paso Robles		
1	Pump septic tank (up to 1200-gallons)	595.00	595.00
300	Overage (1500-gallon septic tank)	0.35	105.00
1	Minimum 1 hour labor to excavate one side of septic tank 380	175.00	175.00
	address		

There will be an additional \$25 service fee, plus bank fees, added for declined payments.

Total

\$1,870.00

Phone #

E-Mail

Payments/Credits

-\$1,870.00

alliancesepticservice@gmail.com **Balance Due**

\$0.00

8052215493