



40459 HWY 41, SUITE 1
OAKHURST, CA 93644
(559) 642-0490
(800) 350-6528
FAX (559) 642-0495
CA LIC. 477941

July 17, 2023

SEPTIC CERTIFICATION: 41243 PAMELA PLACE, OAKHURST

On above date a sanitation system investigation was concluded at the above location. The following facts and conclusions are based on homeowner/Realtor interviews, County records when available and on site evaluation.

INVESTIGATION

The system reviewed is septic in type and services a single-family dwelling approx. 43-years of age. Prior occupancy was 2 people. The house has been vacant for approximately one year.

A check with MCEH revealed As Built dated December 13, 1979.

The primary chamber to the septic tank was excavated and reviewed. The tank was determined to be a precast concrete vessel with a capacity of 1500-gallons in the standard 2/3-1/3 configuration. The no significant scum mat or sludge layer was noted. Pumping is not required. Fluid level was at the invert of the outlet, the normal level.

The area of the leach field was identified by one NDS valve and a single rock leach line. The inspection port was checked and found to be dry, showing no signs of prior elevated effluent level. Vegetal growth does not suggest pending or prior field failure. No above ground discharge of effluent was noted.

OPINIONS-CONCLUSIONS-RECOMMENDATIONS

This system is certified in operational condition, as a low flow design based on current occupancy. No warranties either expressed or implied accompany this document. This document is based solely on the hydraulic loading provided by current occupant. Changes in loading or use experience may adversely affect the efficient operation of this system.

Submitted By:

A blue ink signature of Joel P. Bales is written over the text "Submitted By:". The signature is stylized and cursive.

Joel P. Bales

President

Biological Technology Inc.