

04/03/00 MON 14:27 FAX 805 2381237
05/30/00 14:28

Lake Country Properties

002

MTY CO ENV HEALTH SALINAS → 918052381237

NO. 018

001

RD

~~Hidden Valley~~ Copperhead Rd.**QUADRUPLICATE**
Use of comply with
local requirements

STATE OF CALIFORNIA

THE RESOURCES AGENCY

Do not fill in

DEPARTMENT OF WATER RESOURCES
WATER WELL DRILLERS REPORT

No. 158036

Office of Current No. 190777
Local Permit No. or Date M-3163

State Well No.

Other Well No.

1) OWNER: Name William & Marianne Lang
Address P.O. Box 1825
City Paso Robles, CA Zip 934472) LOCATION OF WELL (See Instructions):
County Monterey Owner's Well Number

Well address if different from above Hidden Valley Land Assoc

Township APN 606-05-341

Distance from cities, roads, railroads, fences, etc.

(12) WELL LOG: Total depth 408 ft. Depth of completed well 405 ft.

from ft. to ft. Formation (Describe by color, character, size or material)

0 - 3 Top Soil

3 - 10 Dk. Brown Sandstone

10 - 33 Lt. Brown Sandy Clay

33 - 37 Lt. Blue Sandstone

37 - 49 Brown Sandstone

49 - 67 Blue Sandstone & Blue Clay

67 - 69 Brown Clay

69 - 86 Sandy Blue Clay

86 - 177 Blue Sandstone & Sandy Blue C

177 - 208 Blue Sandstone

208 - 322 Sandy Blue Clay

322 - 408 Blue Sandstone & Sandy Blue

Clay mix

(3) TYPE OF WORK:

New Well ☒ Deepening ☐Reconstruction ☐Reconditioning ☐Horizontal Well ☐Destruction ☐ (Describe
destruction materials and
procedures in Item 18)

(4) PROPOSED USE:

Domestic ☒Irrigation ☐Industrial ☐Test Well ☐Stock ☐Municipal ☐Other ☐If cap of this well is removed
by anyone other than Aqua
Engineering, Awalt & Son, or
persons authorized by Aqua
Engineering, all structural
warranties are null and void.

WELL LOCATION SKETCH

5) EQUIPMENT:

Rotary ☒Cable ☐Other ☐Reverse ☐Air ☐Bucket ☐

(6) GRAVEL PACK:

Yes ☒ No ☐

Diameter of bore 8-3/4"

Packed from 50 to 405 ft.

7) CASING INSTALLED:

Steel ☐ Plastic ☒ Concrete ☐

(8) PERFORATIONS:

Type of perforation or size of screen

From ft. To ft. Dia. in. Casing or Wall

0 405 5 CL160

From ft. To ft. Slot size

405 345 1/2" drilled

16 rows

3/4" centers

9) WELL SEAL:

Was surface sanitary seal provided? Yes ☒ No ☐ If yes, to depth 50 ft.Were stains sealed against pollution? Yes ☐ No ☒ Interval

Method of sealing cement

10) WATER LEVELS:

Depth of first water, if known 285 ft.

Standing level after well completion 155 ft.

11) WELL TESTS:

Was well test made? Yes ☒ No ☐ If yes, by whom? Aqua Eng.Type of test Pump ☒ Bailor ☐ Air lift ☐

Depth to water at start of test 155 ft. At end of test 155 ft.

Discharge 3-5 gal/min after 1 hour Water temperature

Chemical analysis made? Yes ☐ No ☒ If yes, by whom?Was electric log made? Yes ☐ No ☒ If yes, attach copy to this report

Work started 10-26-84 Completed 10-31-84

WELL DRILLER'S STATEMENT:

This well was drilled under my supervision and this report is true to the best of my knowledge and belief.

SIGNED

(Well Driller)

NAME AQUA ENGINEERING

(Person, firm, or representative) (Typed or printed)

Address P.O. Box 398

City San Miguel, CA Zip 93451

License No. 348058

Date of this report 11-1-84

PWR 198 (REV. 7-78)

IF ADDITIONAL SPACE IS NEEDED, USE NEXT CONSECUTIVELY NUMBERED FORM

Rex 467-9520
FAX