

San Luis Obispo County

Lot #9

FARM SUPPLY COMPANY

Tank Farm Road • P.O. Box 111
San Luis Obispo, CA 93406
Phone (805) 543-3751

1108 Paso Robles Street P.O. Box 1288
Paso Robles, CA 93446
Phone (805) 238-1177

PUMP TEST REPORT

Customer Roger BROWN / Montecito Ridge Date 9-30-03
Address Hwy 227 / Carpenter Cyn.
City & State Arroyo Grande CA
Location of Test Lot # 9

TEST INFORMATION:

Time	Pumping Level	G.P.M.
3:30 PM	247'	10.0
45	248'	10.0
4:00	248'	10.0
15	248'	10.0
30	248'	10.0
45	248'	10.0
5:00	248'	10.0
15	248'	10.0
30	248'	10.0
6:00	248'	10.0
:30	248'	10.0
7:00	248'	10.0
:30	248'	10.0

WELL INFORMATION:

Well size 5" Well depth 520'
Test pump size 3 HP 18 GPM
Standing level 247' Pumping level 504'
Hours of Running 4 Hours
Test started 3:30 PM Shut down 7:30 PM
Recovery Full Recovery in 1 min.

Additional Information:



CREEK ENVIRONMENTAL LABORATORIES, INC.

141 SUBURBAN ROAD, SUITE C-5 • SAN LUIS OBISPO, CA 93401 • (805) 545-9838 • FAX (805) 545-0107

Page 1

Jon Kelley
Farm Supply Company - SLO
675 Tank Farm Road
San Luis Obispo, CA 93401

Log Number: 03-C10304
Order: K3801
Project: Montecito Ridge
Received: 10/01/03

REPORT OF ANALYTICAL RESULTS

SAMPLE DESCRIPTION	SAMPLED BY	SAMPLED		MATRIX	
		DATE @ TIME			
Lot 9 - Roger Brown	Jim Bustamante	09/30/03@19:00		Drinking Water	
ANALYTE	RESULT	* R.L.	UNITS	METHOD	ANALYZED
Total Alkalinity as CaCO ₃	50	2	mg/L	SM 2320B	10/13/03
Chloride	45	1	mg/L	EPA 300.0	10/01/03
Total Cyanide	Not Detected	0.01	mg/L	EPA 335.2	10/13/03
Color	1	1	units	SM 2120B	10/01/03
Electrical Conductance	340	1	umhos/cm	SM 2510	10/01/03
Fluoride	1.2	1	mg/L	EPA 300.0	10/01/03
Langlier Index (Corrosivity)	-1.7	---	pH units	SM 2330B	10/15/03
MBAS (Anionic Surfactants)	Not Detected	0.05	mg/L	SM 5540 C	10/02/03
Nitrate as N	Not Detected	0.1	mg/L	EPA 300.0	10/01/03
Nitrate as NO ₃	Not Detected	0.4	mg/L	EPA 300.0	10/01/03
Nitrite as N	Not Detected	0.1	mg/L	EPA 300.0	10/01/03
Odor	Not Detected	1	TON	SM 2150B	10/01/03
pH	6.9	0.1	units	EPA 150.1	10/01/03
Sulfate	24	0.5	mg/L	EPA 300.0	10/01/03
Total Dissolved Solids	260	10	mg/L	EPA 160.1	10/05/03
Turbidity	2.3	0.1	NTU	EPA 180.1	10/01/03
Total Coliform Bacteria	Absent	---		MMO-MUG	10/01/03
Silver	Not Detected	0.01	mg/L	EPA 200.7	10/08/03
Aluminum	0.06	0.05	mg/L	EPA 200.7	10/08/03
Arsenic	0.024	0.002	mg/L	EPA 200.9	10/14/03
Barium	Not Detected	0.1	mg/L	EPA 200.7	10/08/03
Beryllium	Not Detected	0.001	mg/L	EPA 200.7	10/08/03
Calcium	14	0.03	mg/L	EPA 200.7	10/08/03
Hardness	50	1	mg/L CaCO ₃	EPA 200.7	10/08/03
Cadmium	Not Detected	0.001	mg/L	EPA 200.9	10/08/03
Chromium	Not Detected	0.01	mg/L	EPA 200.7	10/08/03
Copper	Not Detected	0.05	mg/L	EPA 200.7	10/08/03
Iron	0.1	0.1	mg/L	EPA 200.7	10/08/03
Mercury	Not Detected	0.001	mg/L	EPA 245.1	10/08/03
Potassium	3.0	0.1	mg/L	EPA 200.7	10/08/03



CREEK ENVIRONMENTAL LABORATORIES, INC.

141 SUBURBAN ROAD, SUITE C-5 • SAN LUIS OBISPO, CA 93401 • (805) 545-9838 • FAX (805) 545-0107

Page 2

Jon Kelley
Farm Supply Company - SLO
675 Tank Farm Road
San Luis Obispo, CA 93401

Log Number: 03-C10304
Order: K3801
Project: Montecito Ridge
Received: 10/01/03

REPORT OF ANALYTICAL RESULTS

SAMPLE DESCRIPTION	SAMPLED BY	SAMPLED		MATRIX	
		DATE @ TIME			
Lot 9 - Roger Brown	Jim Bustamante	09/30/03@19:00	Drinking Water		
ANALYTE	RESULT	* R.L.	UNITS	METHOD	ANALYZED
Magnesium	2.6	0.03	mg/L	EPA 200.7	10/08/03
Manganese	0.05	0.03	mg/L	EPA 200.7	10/08/03
Sodium	52	0.05	mg/L	EPA 200.7	10/08/03
Nickel	Not Detected	0.01	mg/L	EPA 200.7	10/08/03
Lead	Not Detected	0.005	mg/L	EPA 200.9	10/06/03
Antimony	Not Detected	0.006	mg/L	EPA 200.9	10/08/03
Selenium	Not Detected	0.005	mg/L	EPA 200.9	10/14/03
Thallium	Not Detected	0.001	mg/L	EPA 200.9	10/15/03
Zinc	Not Detected	0.05	mg/L	EPA 200.7	10/08/03

* R.L. - Reporting Limit. 'RESULTS' reported as "Not Detected" means not detected above R.L.

CREEK ENVIRONMENTAL LABORATORIES

Lab Director, Orval Osborne

C. S. LICHTSEITNER ET AL.

San Luis Obispo County

FARM SUPPLY CO.

CUSTOMER SERVICE CARD

WELL

NAME

ADDRESS

PHONE

PUMP MODEL NUMBER

MOTOR HP

PG&E METER

STANDING WATER LEVEL

PIPE SIZE

PRESS TANK SIZE

DISCHARGE PIPE SIZE

PRESS SWITCH SETTING IN OUT MODEL

LOCATION OF WELL

MAP

DATE 9-29-03

SERIAL

PHASE

WELL SIZE

DEPTH 520

PVC ☐ GALV ☐

STORAGE

TANK SIZE

SERVICE CALLS

DATE

9-30-03 10:00 AM 10:00 AM
Level 24" 10:00 AM to 10:00 AM
10:00 AM to 10:00 AM. 10:00 AM

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE

DATE