SEPTAGE PUMPER REPORT

Only domestic household-type waste from Butte County will be accepted at the NRRWF and SC-OR facilities. All wastes must comply with NRRWF and SC-OR resolutions and policies. SC-OR only accepts waste within its sphere of influence. Neither site accepts grease, and may, at random, sample and analyze truck loads as necessary to assure compliance with County, State, and Federal waste discharge limitations.

Contact and System Information

APN #:

Property Owner Name: Darlene Freeman Telephone:

Parcel Address: 15070 Pmon. Rd, Magalia

Property Owner Mailing Address: Same as Property Address: ☐

Residence Currently Occupied? Yes ☐ No ☒ Number of Occupants (if known):

Pump to Gravity Dispersal? Yes ☐ No ☒ Pumping Required? Yes ☐ No ☒ Signal Floats Operational? Yes ☐ No ☐ N/A ☒

Septic Tank Physical Observations

	Concrete	Fiberglass	Poly	Metal	Wood	Good Condition	None Present	Needs Repair or Replacement
Risers:	☐	☐	☐	☐	☐	☐	☒	☐*
Dividing Baffle:	☐	☒	☐	☐	☐*	☒	☐*	☐*
Top of Tank (Lid):	☐	☒	☐	☐*	☐*	☒		☐*
Tank:	☐	☒	☐	☐*	☐*	☒		☐*

Septic Tank Lid Depth: 10 inches/feet (circle one) Inlet/Outlet Ts in good condition: Yes ☒ No ☐* None ☐*

Drainfield Condition: ☒ No problems noted ☐ Backflow into tank* ☐ Surfacing Sewage*

Date Pumped: Amount pumped: 0 gallons Tank Size: 1000 gallons

Sketch of Tank Location

Septic Tank Operational Observations

Scum Inlet: 0 Inches Outlet: 0 Inches

Sludge Inlet: 4 Inches Outlet: 0 Inches

Effluent Level Before Pumping:
☒ Normal
☐ Higher than tank outlet*
☐ Lower than tank outlet*

Sewage Surfacing (incl. graywater):
☒ No
☐ Yes*

* = Follow-Up Needed

Customer or Authorized Representative (Certified Pumper)

I certify under penalty of perjury that I am the above named customer (or authorized representative) and the material being pumped does not contain hazardous substances as defined by the California Penal Code 374.8.

Signature Print Name Date

☒ Pumper Sign-Off on Behalf of Property Owner or Authorized Representative

Septage Pumper Certification

If hauling to SC-OR, septage pumped from: ☐ Yellow Svc Area ☐ Blue Sphere of Influence

Company Name: Dobrich Septic Service, Inc Truck License: 430975 Capacity: 3000 gal

I certify under penalty of perjury the information in this report is correct to the best of my knowledge and that the truck does not contain hazardous substances as defined by the California Health and Safety Code 25141(b) or other materials which are deleterious to the ponds or waste treatment plants. No claim is made by this company, either expressed or implied, concerning success or failure of the septic system.

Viltor Woods VILTOR WOODS 9/3/2024

Signature Print Name Date

Additional Information for Escrow Evaluations Only

Escrow Company Name: Telephone:

Escrow Officer: Escrow #:

Inspection Requested by: Telephone:

Water Service: Community ☒ Private Well ☐ Hydraulic Load Test Performed: Yes ☒ No ☐ Water Introduced: 150 Gallons (Note: 150 gal. minimum recommended)

Effluent Pump & Controls Functional Yes ☐ No ☐

Alarms Functional Yes ☐ No ☐

Effluent Line Diverter Valve Present Yes ☐ No ☒ Level Stabilized Below Outlet: Yes ☒ No ☐


Vegetation Growth Over Field(s) inches Distance from Surface Water/Seasonal Drainage (circle one): Feet

Evaluation Summary: ☒ Pass ☐ Fail* Comments:

* = Follow-Up Needed

White – Neal Road Landfill or SC-OR's copy Yellow – Pumper's copy Pink – Homeowner's copy

Updated: November 29, 2016


Fence
Shed
20'4"
7'9"
1000 Gal Tank
BD Deck
HOUSE
FD Deck
CAR PORT
Fence
DRIVEWAY
Pinon
N