Miller Drilling Co.
301 N. Main St.
Templeton, CA 93465
(805) 434-1888

Miller Drilling Co.

Contractors License No. 324634

PUMP TEST REPORT

JO # 15299

Well Owner: Ed Sauret

Billing Address: 1011 Par Avenue

Paso Robles, Calif. 93446

Pump Set: N/A Well # 6" pvc

Pump Size: 1 ½ Well Depth: N/A

Testing Method: Existing Pump

Perf Rec:

APN:

LOCATION 2325 Bella Tierra

Standing Level Before Testing: 74' - 9"

TESTING

TIME	PUMPING LEVEL	WATER CONDITION	WATER OVER BOWLS	GPM
5 M	88' 3"	Clear		27.5
10	91'	"		27.5
15	91' 10"	"		27.5
4 H	97'	"		27.5

Billing Address: 1011 Par Avenue
Paso Robles, Calif. 93446

Pump Size: 1 ½ Well Depth: N/A

Testing Method: Existing Pump

Perf Rec:

APN:

Standing Level Before Testing: 74' - 9"

LOCATION 2325 Bella Tierra

TESTING

TIME	PUMPING LEVEL	WATER CONDITION	WATER OVER BOWLS	GPM
5 M	88' 3"	Clear		27.5
10	91'	"		27.5
15	91' 10"	"		27.5
4 H	97'	"		27.5

NOTES:

Standing Level After Testing: 78' - 6" after 5 minutes

FINAL TEST RESULTS: Produced 27.5 GPM for 4 hours on (date) July 25, 2005

Test Run By: R. Hewitt

CC:

Recorded