

Panico Excavation Inc  
14300 Davenport Road #5A  
Agua Dulce, CA 91390  
(661) 268-4763  
License #1090540

### Septic Certification

Date: 10/3/24

Property Address: 15932 Live Oak Springs Canyon Rd, Santa Clarita, CA 91387

Homeowners Name

Escrow #:

#### Notes/Comments

Tank and leach lines are in good working order and pass certification. No warranty, this certification is only certifying on this date and does not guarantee any issues after certification issuance.

Sign:



Location: Front yard grass, east side of home

Gallon Capacity: 1200

Number of manholes: 2

Number of Compartments: 2

Year Installed: Less than 10 years

Depth: 3ft

Overall Condition: Good

#### Septic System Type

- Conventional
- Non Conventional

#### Septic Tank Type

- Concrete
- Plastic
- Metal
- Other

#### Baffle T Solid Side

- Yes
- No

#### Baffle T Liquid Side

- Yes
- No

#### Clean out by House

- Yes
- No

#### Riser on solid side

- Yes
- No

#### Riser on Liquid Side

- Yes
- No

#### Leach Line Type:

- Infiltrators
- Rock with 4" Pipe
- N/A

Leach Line Length: N/A

#### Water Test

- Pass
- No Pass

#### D Box

- Yes
- N/A

Seepage Pit: YES

Depth: 25ft

Width: 5ft

Overall condition: Fair