



Applied Industrial Microbiology, Inc.
2321 South Melrose Drive, Vista, CA 92081

CHAIN OF CUSTODY

(FQP022B.03)

Page 1 of 1

Phone: (760) 295-0430
Fax: (760) 734-4454
info@aimvistalab.com

For laboratory use only
Lab ID: **9208**

CLIENT INFORMATION New ☐ Existing ☒		BILLING INFORMATION		Temperature: 6°C							
Name:		Billing Address:		IR Thermometer ID#		Temperature requirement met? Yes ☒ No ☐					
Company: Oasis Utility Services				AIM 0256		Holding Time met? Yes ☒ No ☐					
Address: Box 811						Continue with the Analysis: Yes ☒ No ☐ Initials: //					
Julian CA		P.O.#:				Send test results by Email to (Government or Regulatory body):					
Phone: 760-496-4882		Comments:				Turnaround Time: STANDARD ☒ RUSH ☐ Initials: //					
E-Mail: Oasisutilityservices@outlook.com		* 35465 Sunset Lane				TEST(S) REQUESTED					
		* Julian CA 92036									
		* Post CHL									
Do we have a permission to Sub-Contract your sample to another laboratory? YES ☐ NO ☒ Initials: //											
Discard Sample(s) after analysis is done: YES ☒ NO ☐ Initials: //											
SAMPLING DATE	SAMPLING TIME	SAMPLE DESCRIPTION(s)	Matrix	# of Containers	A	B	C	D	E	F	
4-7-25	4pm	1- 35465	DW	1	☒	☒	☐	☐	☐	☐	
		2-			☐	☒	☐	☐	☐	☐	
		3-			☐	☒	☐	☐	☐	☐	
		4-			☐	☒	☐	☐	☐	☐	
		5-			☐	☒	☐	☐	☐	☐	
1- Sample(s) Collected By: Liam		Date: 4-7-25		Time: 4pm		2- Sample(s) Transported By: Liam		Date: 4-8-25		Time: 10am	
(Sign and Print) Liam Lescarance						(Sign and Print) Liam Lescarance					
3- Relinquished By: Liam		Date: 4-8-25		Time: 10:57am		4- Received By: Tracy Tab		Date: 4-8-25		Time: 10:57	
(Sign and Print) Liam Lescarance						(Sign and Print) Tracy Tab					

Extra charges may apply for rush analysis, special sample preparation, non-typical report format, or other non-typical customer request or needs. Unclaimed samples will be discarded after 30 days without customer notification. All the results will be send by Email. Matrix abbreviations: Compost (CP), Cosmetic (COS), Drinking Water (DW), Fertilizer (Ft), Food (FD), Ice (ICE), Ingredient (ING), Leafy Green (LG), Meat (MT), Processed Water (PW), Sea Water (SW), Shellfish (SF), Soil (SO), Sponge (SP), Supplement (SUP), Swab (SB), Waste Water (WW), Water (W)



TEST REPORT

Client Information: Liam Lesperance
Oasis Utility Services
Box 811
Julian, CA 92036

Reference Number: 2519208

Lab ID: 2519208-001

Sample#:

Comment: 35465 Sunset Lane
Julian CA 92036
Post CHL

Report Date: 04/11/2025
Matrix: DRINKING WATER
Collected: 04/07/2025 @ 15:00
Sampled By: Liam Lesperance
Collection Address:
Description: 35465
Received: 04/08/2025 @ 13:41
Date Completed: 04/11/2025

Colilert

<u>Test Parameter</u>	<u>Result</u>	<u>Unit</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Analyzed</u>	<u>Analyst</u>
E.coli	Absent	CFU/ 100 ml	1	0	SM 9223 B	04/08/2025 11:47	XZ
Total Coliform	Absent	CFU/ 100 ml	1	0	SM 9223 B	04/08/2025 11:47	XZ

Approval:


QA Officer
Xzayla Zabiti


Laboratory Director
Hojabr Dezfulian, Ph.D.

RL = Reporting Limit

MCL = Maximum Contaminant Level

N/A = Not Applicable

Page 1 of 1

Unless otherwise noted, sample(s) were received in acceptable condition. The results in this report relate only to the portion of the sample(s) tested. This report shall not be reproduced, except in full, without approval of the laboratory. This document contains confidential commercial information pursuant to 5U.S.C. § 552(b)(4). ©2014 AIM.

DISCLAIMER: Applied Industrial Microbiology laboratory did not collect the analyzed sample(s) and thus accepts no liability with regard to their collection and/or maintenance. Our laboratory relies on the client for all sample information prior to delivery at our address.



Applied Industrial Microbiology, Inc.

CASE NARRATIVE

Prepared for:

Oasis Utility Services
Box 811
Julian, CA 92036

Order#: 2519208**Project:** Lab Analysis

The following samples were received as indicated below and on the attached Chain of Custody record. All analyses were performed within the holding time and with acceptable quality control results unless otherwise noted.

SAMPLE ID	LAB ID	MATRIX	Date Collected	Date Received
	2519208-001	DRINKING WATER	04/07/2025	04/08/2025

Sample Container (lot number: w/ Sodium Thiosulfate, 20230612347, exp. 06/11/2026).
Volume Check: PASS
Sterility Test: PASS
Auto Fluorescence Test: PASS

Sample container was filled above 100mL when received. Sample was transferred to a larger sterile container, shaken, and 100mL of sample was measured, then poured into the original container and tested.

Colilert Media (lot number: FY042, exp. 7/14/2025).
Sterility Test: PASS
Performance Test: PASS
Auto Fluorescence Test: PASS


Ultraviolet Lamp
Fluorescence: PASS
Fluorescent Bulb Changed on 04/01/2025

Colilert Comparator (lot number: KY136, exp. 10/31/2025).
Positive and Negative controls: PASS

The enclosed results of analyses are representative of the samples as received by the laboratory. Applied Industrial Microbiology, Inc. makes no representations or certifications as to the methods of sample collection, sample identification, or transportation handling procedures used prior to our receipt of samples. To the best of my knowledge, the information contained in this report is accurate and complete.

Approval:


QA Officer
Xzayla Zabiti


Laboratory Director
Hojabr Dezfulian, Ph.D.

Applied Industrial Microbiology, Inc.
2321 South Melrose Drive, Vista, CA 92081
Phone: (760)-295-0430 Fax: (760)-734-4454
Info@aimvitalab.com