

# L A B O R A T O R Y   R E P O R T

Telephone (619) 425-1993

Fax 425-7917

Established 1928

C L A R K S O N   L A B O R A T O R Y   A N D   S U P P L Y   I N C.  
350 Trousdale Dr. Chula Vista, Ca. 91910   [www.clarksonlab.com](http://www.clarksonlab.com)  
A N A L Y T I C A L   A N D   C O N S U L T I N G   C H E M I S T S

Date: March 22, 2022

Purchase Order Number: NONE

Sales Order Number: 55028

Account Number: B.EASC

To:

\*-----\*

East County Pump Service & Well Drilling

22011 Japatul RD

Alpine, CA 91901

Attention: Dan Wasson

Laboratory Number: B9880

Customers Phone: 445-8828

Fax:

Sample Designation:

\*-----\*

One water sample received on 03/21/22 at 10:50am,  
taken on 03/21/22 at 9:38am by Sergio Martinez  
from 17869 Lyons Uly Rd, Jamul CA 91935  
marked as Drinking Water from Well Head.

ANALYSIS: Per EPA Drinking Water, National Primary  
Drinking Water Regulations.

Test Method Colilert (MMO-MUG) SM 9223B


Total Coliform is ABSENT.

Fecal Coliform (E.Coli) is ABSENT.

	Sample Result (mg/L)	Minimum Detection Limit (mg/L)	APHA Test Method No.
	-----	-----	-----
Nitrate as Nitrogen (NO <sub>3</sub> -N)	<0.4	0.4	4500NO <sub>3</sub> D

Note:     <     Is the symbol for less than.

         \* = Exceeds the maximum contamination level of  
             10 mg/L Nitrate as Nitrogen for Drinking Water.



Rosa Bernal

RMB/js