

COUNTY OF SAN DIEGO
DEPARTMENT OF PUBLIC HEALTH

STEWART

Page 1 of 2 pages

WELL PERMIT APPLICATION

1600 PACIFIC HIGHWAY

SAN DIEGO, CA. 92101

Permit No. 27297


TYPE OF WORK (Check) New Well ☒ Repair or Modification ☐ Time Extension ☐ Destruction ☐		USE (Check) Individual Domestic ☒ Agricultural ☐ Industrial ☐ Commercial ☐ Community ☐ Other ☐		EQUIPMENT (Check) Rotary ☒ Cable Tool ☐ Other ☐	
PROPOSED WELL DEPTH Max. 120 Min. 100 (Feet)		PROPOSED CASING Type STEEL Depth 120 Diameter 5 9/16 Wall or Gage 136			
PROPOSED SEALING ZONE(S) From 0 to 20 Feet From _____ to _____ Feet From _____ to _____ Feet			SEALING MATERIAL (Check) Neat Cement ☒ Puddled Clay ☐ Cement Grout ☐ Concrete ☐		
PROPOSED PERFORATIONS OR SCREEN From 60 to 120 Feet From _____ to _____ Feet From _____ to _____ Feet From _____ to _____ Feet			DATE OF WORK Start 5/30/79 Completion 6/1/79		
NAME OF WELL OWNER STEWART TITLE CO. TR.			NAME OF WELL DRILLER D.B. TRUNNEL		
LOCATION OF WELL SHEETER VALLEY			COMPANY AMERICAN DRILLING		
DISPOSITION OF APPLICATION (FOR HEALTH OFFICERS USE ONLY) ☐ APPROVED ☐ DENIED ☒ APPROVED WITH CONDITIONS			BUSINESS ADDRESS 92302 Box 278 AGUANGA CA LICENSE NUMBER 324684 Cash Deposit ☐ Bond Posted ☒		
Report Reason(s) for Denial or Necessary Conditions Here: approved with the following conditions: 1. all work to be done to state and local codes 2. well to be 50' from property line to west NONE			\$25 Fee paid on 5-18-79 NO16565		
HEALTH OFFICER TW... 18 May 79 DATE			APPLICANT'S SIGNATURE D.B. Trunnel 5/15/79 DATE		

Permit No. _____

Assessor's Parcel No. 251-180-11

LOCATION

INDICATE BELOW THE EXACT LOCATION OF WELL WITH RESPECT TO THE FOLLOWING ITEMS: PROPERTY LINES, WATER BODIES OR WATER COURSES, DRAINAGE PATTERN, ROADS, EXISTING WELLS, SEWERS AND PRIVATE SEWAGE DISPOSAL SYSTEMS. INCLUDE DIMENSIONS.



QUADRUPLICATE 4
Use to comply with
local requirements

STATE OF CALIFORNIA
THE RESOURCES AGENCY
DEPARTMENT OF WATER RESOURCES
WATER WELL DRILLERS REPORT

Do not fill in
No. 059434

Notice of Intent No. _____

Local Permit No. or Date 5-18-79 272 96

State Well No. _____

Other Well No. _____

The information in this grayed area has been blocked from public viewing pursuant to section 13752 of the Water Code and the Information Practice Act of 1977, to protect personal information.

(12) WELL LOG: Total depth 120 ft. Depth of completed well 120 ft.
from ft. to ft. Formation (Describe by color, character, size or material)

0 - 15 Top soil
15 - 37 Sand & clay
37 - 45 Gravel
45 - 75 Firm sand
75 - 97 Gravel
97 - 110 Sand & clay
110 - 120 Coarse sand

(2) LOCATION OF WELL (See instructions):

County San Diego Owner's Well Number _____


Well address if different from above Shelter Valley Ranchos

Township _____ Range _____ Section _____

Distance from cities, roads, railroads, fences, etc. _____

Tax Parcel # 251-180-11

LOT 83



WELL LOCATION SKETCH

(3) TYPE OF WORK:

New Well ☒ Deepening ☐

Reconstruction ☐

Reconditioning ☐

Horizontal Well ☐

Destruction ☐ (Describe destruction materials and procedures in Item 12)

(4) PROPOSED USE:

Domestic ☒

Irrigation ☐

Industrial ☐

Test Well ☐

Stock ☐

Municipal ☐

Other ☐

(5) EQUIPMENT:

Rotary ☒ Reverse ☐

Cable ☐ Air ☐

Other ☐ Bucket ☐

(6) GRAVEL PACK:

Yes ☒ No ☐ Size 2/16 X 7 1 yard

Diameter of bore 10"

Packed from _____ to _____

(7) CASING INSTALLED:

Steel ☒ Plastic ☐ Concrete ☐

(8) PERFORATIONS:

Type of perforation or size of screen

From ft.	To ft.	Dia. in.	Cage or Wall	From ft.	To ft.	Slot size
0	120	6 5/8	8.156	60	120	6 rows 12 cuts 2 1/2 X 1/8

(9) WELL SEAL:

Was surface sanitary seal provided? Yes ☒ No ☐ If yes, to depth 20 ft.

Were strata sealed against pollution? Yes ☐ No ☒ Interval _____

Method of sealing sanitary seal, cement & steel casing

(10) WATER LEVELS:

Depth of first water, if known _____ ft.

Standing level after well completion _____ ft.

(11) WELL TESTS:

Was well test made? Yes ☒ No ☐ If yes, by whom? driller

Type of test Pump ☐ Bailer ☐ Air lift ☒

Depth to water at start of test _____ ft. At end of test _____ ft.

Discharge 50 gal/min after _____ hours Water temperature _____

Chemical analysis made? Yes ☐ No ☒ If yes, by whom? _____

Was electric log made? Yes ☐ No ☒ If yes, attach copy to this report

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

SIGNED Donald B. Jewell

NAME AMERICAN DRILLING, INC.

Address 104 W. Main (Typed or printed)

City Aguanga, CA Zip 92302

License No. 324684 Date of this report May 31, 1979