Backcountry Analytical

1 Hour Flow Test

Flow Data Report

7256 Cosmit Lane Julian,CA 92036

Date:__5/17/26_____

Start Tim 11:15 AM **End Time 12:15 AM**

	Gal/Min
15 Min	7.354
30 Min	7.349
45Min	7.374
60 Min	7.374
AVG Gal/Min	7.36275

PSI__58__

Total gals Pumped___887__

[Operator] Matthew Earnhart

5/20/26
Date

The pump perfomed to industrty stadards as intended.