



WOOD DESTROYING PESTS AND ORGANISMS INSPECTION REPORT

Building Address: 9970 Mesa Madera Dr., San Diego, CA 92131		Date of Inspection 10/17/2025	Number of Pages 6
		4740 Mission Gorge Pl. #601012 San Diego, CA 92160 Ph: (619) 439-7188 info@adapestcontrol.com	
Report # W8431		Lic. Registration # PR 9098	
Escrow #			
Ordered by: Compass Sean Blake 12860 El Camino Real 100 San Diego, CA 92130	Property Owner and/or Party of Interest: Compass Sean Blake 12860 El Camino Real 100 San Diego, CA 92130	Report Sent to: Compass Sean Blake 12860 El Camino Real 100 San Diego, CA 92130	
COMPLETE REPORT ☒ LIMITED REPORT ☐ SUPPLEMENTAL REPORT ☐ REINSPECTION REPORT ☐			
General Description: One stucco single family residence with attached garage and composition roof on slab foundation.		Inspection Tag Posted: Attic Other Tags Posted: None Noted	
An inspection has been made of the structure(s) shown on the diagram in accordance with the Structural Pest Control Act. Detached porches, detached steps, detached decks and any other structures not on the diagram were not inspected.			
Subterranean Termites ☐ Drywood Termites ☒ Fungus / Dryrot ☒ Other Findings ☐ Further Inspection ☐			
If any of the above boxes are checked, it indicates that there were visible problems in accessible areas. Read the report for the details on checked items.			



This Diagram is not to scale

Inspected by: Alex Jaimes State License No. OPR14176 Signature 

You are entitled to obtain copies of all reports and completion notices on this property reported to the Structural Pest Control Board during the preceeding two years. To obtain copies contact: Structural Pest Control Board, 2005 Evergreen Street, Ste. 1500, Sacramento, California 95815.

NOTE: Questions or problems concerning the above report should be directed to the manager of the company. Unresolved questions or problems with the services performed may be directed to the Structural Pest Control Board at (916) 561-8708, (800) 737-8188 or www.pestboard.ca.gov 43M-41

SECOND PAGE OF STANDARD INSPECTION REPORT OF THE PROPERTY LOCATED AT:

Address 9970 Mesa Madera Dr., San Diego, CA 92131

10/17/2025

W8431

Date

Report #

What Is a Wood Destroying Pest and Organism Inspection Report?

The following explains the scope and limitations of a structural pest control inspection and a Wood Destroying Pest & Organism Inspection Report.

A Wood Destroying Pest & Organism Inspection Report contains findings as to the presence or absence of wood destroying insects or organisms in visible and accessible areas on the date of inspection and contains our recommendations for correcting any infestations, infections, or conditions found. The contents of the wood destroying pest & organism inspection report are governed by the structural pest control act and its rules and regulations.

Some structures may not comply with building code requirements or may have structural, plumbing, electrical, heating and air conditioning, or other defects that do not pertain to this report. This report does not address any such defects as they are not within the scope of the license of the inspector or the company issuing this report.

The following areas are considered inaccessible for purposes of inspection or are not included in a normal inspection report and therefore are excluded in this report: the interior of hollow walls; spaces between an upstairs floor and the ceiling below or a porch deck and soffit below; stall showers over finished ceilings; such structural segments as areas enclosed by bay windows, buttresses, built-in cabinet work, areas under floor covering; any areas requiring the removal of storage, furnishings or appliances; and any areas to which there is no access without defacing or removing lumber, masonry or finished workmanship.

Certain areas are recognized by the industry as inaccessible and/or for other reasons not inspected. These areas include, but are not limited to: inaccessible and/or insulated attics or portions thereof, attics with less than an 18" clear crawl space, the interior of hollow walls, spaces between a floor or porch deck and the ceiling below, areas where there is no access without defacing or tearing out lumber, masonry or finished work that make inspection impractical, and areas or timbers around eaves that would require use of an extension ladder.

Certain areas may be inaccessible for inspection due to construction or storage. We recommend further inspection of areas where inspection was impractical. Re: Structural Pest Control Act, Business and Professions Code Article 1, 8516(b)(9). Stall shower, if any, is water tested in compliance with Title 16 Professional and Vocational Regulations Article 5, §1991.1(12) of the Structural Pest Control Act. The absence or presence of leaks through sub-floor, adjacent floors or walls will be reported. This is a report of the condition of the stall shower at the time of inspection only, and should not be confused as a guarantee. Although we make a visual examination, we do not deface or probe into window or door frames, decorative trim, roof members, etc., in search of wood destroying pests or organisms.

"This company will reinspect repairs done by others within four months of the original inspection. A charge, if any, can be no greater than the original inspection fee for each reinspection. The reinspection must be done within ten (10) working days of request. The reinspection is a visual inspection and if inspection of concealed areas is desired, inspection of work in progress will be necessary. Any guarantees must be received from parties performing repairs."

NOTE: We do not inspect or certify plumbing, plumbing fixtures, etc.

NOTE: "The exterior surface of the roof was not inspected. If you want the water tightness of the roof determined, you should contact a roofing contractor who is licensed by the Contractors' State License Board."

"NOTICE: The charge for service that this company subcontracts to another registered company may include the company's charges for arranging and administering such services that are in addition to the direct costs associated with paying the subcontractor. You may accept ADA Termite and Pest Control's bid or you may contract directly with another registered company licensed to perform the work.

If you choose to contract directly with another registered company, ADA Termite and Pest Control will not in any way be responsible for any act or omission in the performance of work that you directly contract with another to perform."

"NOTICE: Reports on this structure prepared by various registered companies should list the same findings (i.e. termite infestations, termite damage, fungus damage, etc.). However, recommendations to correct these findings may vary from company to company. You have a right to seek a second opinion from another company."

This Wood Destroying Pest & Organisms Report DOES NOT INCLUDE MOLD or any mold like conditions. No reference will be made to mold or mold-like conditions. Mold is not a Wood Destroying Organism and is outside the scope of this report as defined by the Structural Pest Control Act. If you wish your property to be inspected for mold or mold-like conditions, please contact the appropriate mold professional.

"Local treatment is not intended to be an entire structure treatment method. If infestations of wood-destroying pests extend or exist beyond the area(s) of local treatment, they may not be exterminated."

THIRD PAGE OF STANDARD INSPECTION REPORT OF THE PROPERTY LOCATED AT:

Address 9970 Mesa Madera Dr., San Diego, CA 92131

10/17/2025

W8431

Date

Report #

CONDITIONAL GUARANTEE: ADA Termite and Pest Control guarantees all work performed by this company for one year and subcontract work is guaranteed for 30 days. This company is not responsible for any future infestation, dry rot, or adverse conditions beyond the time of inspection. If a fumigation is performed, ADA Termite and Pest Control is not liable for any damage to shrubs, vines, trees, etc., or any damage to roofs or roof members at the time of fumigation. In the event that a re-treatment, re-fumigation, or any other repair work is to be performed to honor a guarantee issued by ADA Termite and Pest Control, the home owner is responsible to make the property available for any work to be performed. ADA Termite and Pest Control will not be liable for any cost of vacating or preparing the residence for re-treatment and/or repairs. NOTE: A new and/or extension of guarantee is never given for re-treatments done under original guarantee.

NOTE: The bid below includes Standard Readily Available Lumber. Old or custom sized materials will be replaced with an available alternative. Custom order or special milled items will only be used when the person(s) ordering the corrective work makes a special request. All custom ordered or special milled items will be ordered only after the approval of additional costs.

NOTE: All repair bids on this report are to repair existing structures as noted on our report. It is the responsibility of the owner of this property to inform ADA Termite and Pest Control if some existing structure being repaired is not permitted or not built to code. It is the property owner's responsibility prior to approving any repairs to check with the City Building Dept. to see if permits are required for the work estimated below. If required, the property owner will need to pull permits as an owner builder and notify ADA Termite and Pest Control. Any additional work required by City Building Dept. and/or field inspectors will be at an additional cost.

This is a separated report which is defined as Section I/Section II conditions evident on the date of the inspection. Section I contains items where there is visible evidence of active infestation, infection or conditions that have resulted in or from infestation or infection. Section II items are conditions deemed likely to lead to infestation or infection but where no visible evidence of such was found. Further inspection items are defined as recommendations to inspect area(s) which during the original inspection did not allow the inspector access to complete the inspection and cannot be defined as Section I or Section II.

FINDINGS AND RECOMMENDATIONS

NOTE: Portions in the attic were concealed or made inaccessible due to inadequate crawl space and or insulation. There is no economical or practical method to to make these areas accessible. No opinion or guarantee is expressed or implied in these areas.

NOTE: The interior garage walls are finished and therefore the framing was inaccessible for inspection. There is no economical or practical method to make this area accessible for inspection. No opinion or guarantee is expressed or implied in this area.

Attic Spaces:

7A (Section I)
FINDINGS: Evidence of drywood termite infestation at attic framing as indicated on the diagram.
RECOMMENDATION: Vacate the premises and seal the structure for fumigation with Vikane Gas. Remove or cover accessible evidence of infestation. Fumigation warranted for three years. Fumigation awareness notice must be signed prior to fumigation. See fumigation notice for terms and liabilities. ALL FUMIGATIONS CANCELED LESS THAN 72 HOURS PRIOR TO SCHEDULED DATE WILL BE SUBJECT TO A CANCELLATION FEE OF \$150.00.

Garages:

8A (Section I)
FINDINGS: Evidence of drywood termite infestation at garage framing as indicated on the diagram.
RECOMMENDATION: Vacate the premises and seal the structure for fumigation with Vikane Gas. Remove or cover accessible evidence of infestation. Fumigation warranted for three years. Fumigation awareness notice must be signed prior to fumigation. See fumigation notice for terms and liabilities. ALL FUMIGATIONS CANCELED LESS THAN 72 HOURS PRIOR TO SCHEDULED DATE WILL BE SUBJECT TO A CANCELLATION FEE OF \$150.00.

Address 9970 Mesa Madera Dr., San Diego, CA 92131

10/17/2025

W8431

Date

Report #

- Findings and Recommendations continued from previous page -

Other Exterior:

- 11A (Section I)
FINDINGS: Evidence of drywood termite infestation at eaves/siding as indicated on the diagram.
RECOMMENDATION: Vacate the premises and seal the structure for fumigation with Vikane Gas. Remove or cover accessible evidence of infestation. Fumigation warranted for three years. Fumigation awareness notice must be signed prior to fumigation. See fumigation notice for terms and liabilities. ALL FUMIGATIONS CANCELED LESS THAN 72 HOURS PRIOR TO SCHEDULED DATE WILL BE SUBJECT TO A CANCELLATION FEE OF \$150.00.
- 11B (Section I)
FINDINGS: Drywood termite/fungus damage to the fascia/joists as indicated on the diagram.
RECOMMENDATION: Remove and or repair/reinforce infected /damaged wood members and replace with new materials as necessary. Chemically treat surrounding wood members with a registered fungicide/termiticide as needed. Paint to match ins included in this estimate. Exact match not guaranteed.
- Should damage during repairs extend into inaccessible areas, the owner/agent will be immediately notified, and a supplemental report will be issued with an additional cost estimate.
- 11C (Section I)
FINDINGS: Drywood termite/fungus damage to the column collar/trim as indicated on the diagram.
RECOMMENDATION: Remove and or repair/reinforce infected /damaged wood members and replace with new materials as necessary. Chemically treat surrounding wood members with a registered fungicide/termiticide as needed. Paint to match ins included in this estimate. Exact match not guaranteed.
- Should damage during repairs extend into inaccessible areas, the owner/agent will be immediately notified, and a supplemental report will be issued with an additional cost estimate.
-

FIFTH PAGE OF STANDARD INSPECTION REPORT OF THE PROPERTY LOCATED AT:

Address 9970 Mesa Madera Dr., San Diego, CA 92131

10/17/2025

W8431

Date

Report #

In accordance with the laws and regulations of the State of California, we are required to provide you with the following information prior to application of pesticides to your property.

"State law requires that you be given the following information: CAUTION--PESTICIDES ARE TOXIC CHEMICALS. Structural Pest Control Companies are registered and regulated by the Structural Pest Control Board, and apply pesticides which are registered and approved for use by the California Department of Pesticide Regulation and the United States Environmental Protection Agency. Registration is granted when the state finds that, based on existing scientific evidence, there are no appreciable risks if proper use conditions are followed or that the risks are outweighed by the benefits. The degree of risk depends upon the degree of exposure, so exposure should be minimized."

"If within 24 hours following application you experience symptoms similar to common seasonal illness comparable to the flu, contact your physician or poison control center (800) 222-1222 and your pest control company immediately."

For further information, contact any of the following:

ADA Termite and Pest Control	(619) 439-7188
Poison Control Center	(800) 222-1222
(Health Questions) County Health Dept.	
Orange County	(714) 834-3155
Los Angeles County	(213) 240-8117
San Bernardino County	(800) 782-4264
Riverside County	(951) 358-5000
San Diego County	(619) 229-5400
(Application Info.) County Agriculture Commission	
Orange County	(714) 955-0100
Los Angeles County	(626) 575-5471
San Bernardino County	(909) 387-2105
Riverside County	(951) 955-3045
San Diego County	(858) 694-2739
Structural Pest Control Board (Regulatory Info.)	(916) 561-8704
2005 Evergreen Street, Ste. 1500 Sacramento, CA 95815	

TERMITE AND FUNGUS CONTROL CHEMICALS

Vikane (EPA Reg. No. 1015-78-AA)
Active Ingredients: Sulfuryl Floride 99.8%

Bora-Care (EPA Reg. No. 64405-1-AA)
Active Ingredients: Disodium OctaborateTetrahydrate 40%

Premise Foam (EPA Reg. No. 432-1391-AA)
Active Ingredients: Imidacloprid 0.05%

Termidor SC (EPA Reg. No. 7969-210-AA)
Active Ingredients: Fipronil 9.1%

NOTICE TO OWNER

Under the California Mechanics Lien Law any structural pest control company which contracts to do work for you, any contractor, subcontractor, laborer, supplier or other person who helps to improve your property, but is not paid for his or her work or supplies, has a right to enforce a claim against your property. This means that after a court hearing, your property could be sold by a court officer and the proceeds of the sale used to satisfy the indebtedness. This can happen even if you have paid your structural pest control company in full if the subcontractor, laborers or suppliers remain unpaid.

To preserve their right to file a claim or lien against your property, certain claimants such as subcontractors or material suppliers are required to provide you with a document entitled "Preliminary Notice." Prime contractors and laborers for wages do not have to provide this notice. A Preliminary Notice is not a lien against your property. Its purpose is to notify you of persons who may have a right to file a lien against your property if they are not paid.

NOTE: If the Home Owner fails to pay billing in full, ADA Termite and Pest Control will have the right to be paid back for all of its costs and expenses to the extent not prohibited by applicable law. Those expenses include, for example (but not limited to), reasonable attorney's fees. If for any reason this account is to be turned over to our collection agency, you will be responsible for all costs of collecting.

SIXTH PAGE OF STANDARD INSPECTION REPORT OF THE PROPERTY LOCATED AT:

Address 9970 Mesa Madera Dr., San Diego, CA 9213110/17/2025W8431

Date

Report #

Findings and Recommendations estimated by this Company:

Item	Approval	Primary Estimate	Section
7A	☐	\$1,825.00	I
8A	☐	Included in 7A	I
11A	☐	Included in 7A	I
11B	☐	\$3,850.00	I
11C	☐	Included in 11B	I

☐ Complete all of the items quoted above with Primary Estimate.**Total Estimate \$5,675.00**☐ Complete only the above Items checked.

Total \$ _____

I have read and understand the terms of the Report referenced above and agree to the terms and conditions set forth.
 ADA Termite and Pest Control is hereby authorized to complete the Items selected above and it is agreed that payment shall be made as follows:

Payment shall be made as follows: ☐ With close of Escrow ☐ \$ _____ Deposit ☐ \$ _____ on Completion

Escrow Number: _____ Escrow Company: _____ Escrow Officer: _____

Phone () _____ - _____ Email: _____ Address: _____

Owner or Authorized Representative: ☐ Owner ☐ Representative's Title: _____

Print Name: _____ X _____ Date _____

Owner or Authorized Representative: ☐ Owner ☐ Representative's Title: _____

Print Name: _____ X _____ Date _____

