

Butler Heating and Air

Kenneth Moore 29419 Shady Lane Murrieta, CA 92563

(323) 316-7966

CONTACT US

38405 Sevilla ave Murrieta, CA 92563

(951) 473-3597

iames.butlerheatingandair@gmail.com

INVOICE

Services	qty	unit price	amount
A/C tune up	2.0	\$60.00	\$120.00

An A/C tune-up keeps your air conditioning system in good working order. It includes:

- Inspect coolant levels & pressure
- Check & adjust thermostat
- Inspect wiring, contacts, capacitors & relays
- Inspect and clean condenser
- Inspect outdoor disconnect
- Inspect condenser fan motor & blades
- Inspect compressor at startup

When completed you will receive a recommendation for any further maintenance or repair needs of your system.

Sul	ototal		\$120.00
Jol	o Total		\$120.00
An	nount Due		\$0.00
Payment F	History		
Dec 17	Tue 3:37pm	Check	\$120.00

Downstairs unit- during maintenance checked capacitor, capacitor is in good standing reading 45 when it is desired for 45, contactor is still in good state, all electrical connections are good, refrigerant level is good, Unit is in good running state, indoor air temperature is 54° blowing out, fan motor amps high reading 1.05 when the motor lockout is rated for 1.1 amps but that is due to the coil that is clogged from dogs scratching at the coil. Unit is still running and cooling the desire space

Butler Heating and Air | 1091127 1 of 2

Upstairs system- during maintenance checked capacitor, capacitor is in a good standing reading 44 when it is desired for 45, contactor is still in a good state, all electrical connections are good, refrigerant level is good, indoor air temperature blowing out is 50°, fan motor ants are good reading 0.8 when fan motor amps lockout at 1.5, unit is running good and efficient and cooling the desired space.

Thank You For Your Wonderful Business, Butler Heating And Air Would Really Appreciate It If You Could Leave A Review!!

See our Terms & Conditions

Butler Heating and Air | 1091127 2 of 2