



619-417-9097
Po Box 361
Potrero, CA 91963

Septic Certification

ESP# LSHOP-000057

Name- Robert & Judy Dodson
Street- 308 La Cresta Heights Rd
City and State- El Cajon Ca 92021

Description of Septic systems:

System 1- Fiberglass
Gallon Amount- 1,000
Compartments- Two

Inspection of Septic Systems- Septic tank and leach lines are in good working order. Leach lines pass a 30 minute water test.

Certified Technician

Date- 06-16-2026

A handwritten signature in black ink, appearing to read "Jerry Arnold".

Jerry Arnold

The determination of the viability of this system is based on what we find at this time, which could change dramatically at any time. We inspected this system on the above date, and we offer no guarantee of the future performance of this system.