

Permit No. 27200

SAN DIEGO, CA. 92101


TYPE OF WORK (Check)		USE (Check)		EQUIPMENT (Check)	
New Well	☒	Individual Domestic	☒	Rotary	☐
Repair or Modification	☐	Agricultural	☐	Cable Tool	☐
Time Extension	☐	Industrial	☐	Other AIR	☒
Destruction	☐				
PROPOSED WELL DEPTH		PROPOSED CASING			
Max. 500' Min. 100' (Feet)		Type Steel	Depth 20'	Diameter 6 3/8"	Wall or Gage 1.88
PROPOSED SEALING ZONE(S)		SEALING MATERIAL (Check)			
From 0' to 20' Feet		Neat Cement ☒ Puddled Clay ☐			
From _____ to _____ Feet		Cement Grout ☐ Concrete ☐			
From _____ to _____ Feet					
PROPOSED PERFORATIONS OR SCREEN		DATE OF WORK			
From _____ to _____ Feet		Start 3/28/79			
From _____ to _____ Feet		Completion 3/30/79			
From _____ to _____ Feet					
NAME OF WELL OWNER		NAME OF WELL DRILLER			
Daniel Russell		Bud Fisher			
LOCATION OF WELL East side of Ribbonswood Rd. Blvd. Calif.		COMPANY FISHER & SON'S - Well-Drilling Co.			
DISPOSITION OF APPLICATION (FOR HEALTH OFFICERS USE ONLY)		BUSINESS ADDRESS Rt. 1 - Box 71 Campo Ca. 92006			
☒ APPROVED ☐ DENIED		LICENSE NUMBER 314485		Cash Deposit ☒ Bond Posted ☐	
☐ APPROVED WITH CONDITIONS		\$25 Fee paid on 3/26/79			
Report Reason(s) for Denial or Necessary Conditions Here:		I hereby agree to comply with all regulations of the Department of the Public Health and with all ordinances and laws of the County of San Diego and of the State of California pertaining to well construction, repair, modification and destruction. Immediately upon completion of work I will furnish the Department of Public Health with a complete and accurate log of the well.			
None		Delores R. Fisher			
HEALTH OFFICER		APPLICANT'S SIGNATURE			
3-26-79		3/26/79			
DATE		DATE			


Permit No. _____

Assessor's Parcel No. 611-090-14

LOCATION

INDICATE BELOW THE EXACT LOCATION OF WELL WITH RESPECT TO THE FOLLOWING ITEMS: PROPERTY LINES, WATER BODIES OR WATER COURSES, DRAINAGE PATTERN, ROADS, EXISTING WELLS, SEWERS AND PRIVATE SEWAGE DISPOSAL SYSTEMS. INCLUDE DIMENSIONS.





COUNTY OF SAN DIEGO
DEPARTMENT OF PUBLIC HEALTH
1600 PACIFIC HIGHWAY, SAN DIEGO, CA 92101

Do Not Fill In

WATER WELL DRILLERS REPORT

State Well No. _____

Other Well No. _____

The information in this grayed area has been blocked from public viewing pursuant to section 13752 of the Water Code and the Information Practice Act of 1977, to protect personal information.

(2) LOCATION OF WELL:

County San Diego Owner's number, if any # 1
Township, Range, and Section T-17-S R-7-E S-17
Distance from cities, roads, railroads, etc. East Side of Ribbonwood Road, Boulevard, California

(3) TYPE OF WORK (Check):

New Well ☒ Deepening ☐ Reconditioning ☐ Destroying ☐
If destruction, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) EQUIPMENT:

Rotary ☐
Cable ☐
Other Air ☒

(6) CASING INSTALLED:

STEEL ☒ OTHER Pvc
SINGLE ☒ DOUBLE ☐

If gravel packed

From ft.	To ft.	Diam.	Gage or Wall	Diameter of Bore	From ft.	To ft.
0	20	6.5"	1.88"			
0	360	4"	1.4"	6"	0	360

Size of shoe or well ring:

Size of gravel: 5/16

Describe joint

(7) PERFORATIONS OR SCREEN:

Type of perforation or name of screen

From ft.	To ft.	Perf. per row	Rows per ft.	Size in. x in.
210	360	4	4 per 20'	1/8 x 3

(8) CONSTRUCTION:

Was a surface sanitary seal provided? Yes ☒ No ☐ To what depth 20' ft.

Were any strata sealed against pollution? Yes ☐ No ☒ If yes, note depth of strata From ft. to ft.

Method of sealing

Neat Cement

(9) WATER LEVELS:

Depth at which water was first found, if known 35' ft.
Standing level before perforating, if known 25' ft.
Standing level after perforating and developing 25' ft.

(10) WELL TESTS:

Was pump test made? Yes ☒ No ☐ If yes, by whom? Driller

Yield: 8 gal/min. with ft. drawdown after 2 hrs.

Temperature of water Cold Was a chemical analysis made? Yes ☐ No ☒

Was electric log made of well? Yes ☐ No ☒ If yes, attach copy

(11) WELL LOG:

Total depth 360 ft. Depth of completed well 360 ft.

Formation: Describe by color, character, size of material and structure ft. to ft.

0' - 15' Top Soil and Soft D.G.

15' - 25' med. Hard White Granite

25' - 27' Broken Strata "Rusty Rock"

27' - 205' med. Hard White Granite

205 - 210 Tan or white Clay

210 - 360 Hard White Granite

Work started 5/11 1979 Completed 5/21 1979

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Fisher & Son's Well-Drilling Co.
(Person, firm, or corporation) (Typed or printed)

Address RR-1, Box 71 Campo Ca. 92006

[Signed] Bud Fisher
(Well Driller)

License No. 314485 Dated 5-28 1979

SKETCH LOCATION OF WELL ON REVERSE SIDE

OVER

NORTH BOUNDARY OF SECTION

NW 1/4		NE 1/4	
SW 1/4		SE 1/4	

1/2 MILE

Township 17-S N/S

Range 7-E E/W

Section No. 17

Assessor's Parcel No. 611-090-14

FOR DEPARTMENT USE ONLY

Inspection Data

Predrilling

Date Requested _____

By Whom _____

Inspection Date _____

Sanitarian's Approval _____

A. Location of well in sectionized areas.

Sketch roads, railroads, streams, or other features as necessary.

NORTH

WEST

EAST

SOUTH

Ribbonwood Rd.

10 ACRES
Well site

Free Way 8

old 80

1/2 MILE

Completed Well Construction

Date Requested _____

Well driller's report and Log received in proper form _____

(Yes or No)

Date _____

Date Inspected _____

Comments _____

Sanitarian's Approval _____

Date _____

Bacteriological & Chemical Data

Bac. Sample Taken _____

Required _____ Date _____

Chemical Sample taken _____

Required _____ Date _____

Analysis Acceptable _____

(Chemical)

(Bacteriological)

Approved for operation when bacteriological sample is received.

(Sanitarian)

B. Location of well in areas not sectionized.

Sketch roads, railroads, streams, or other features as necessary.

Indicate distances.