



NEWDOC

DEH APN FILE TARGET SHEET
ARCHIVE RECORD
Pre-KIVA & Existing APN Records

Document Name: LARC _____
(LARC_KIVA Per Num_APN)

Document Type: Legacy Septic System Documents

APN(s) 123-D81-44

Number of Pages: 5

Document Prepared by: NS

Document Preparation Date: 5/7/09

Office Source: San Marcos

6235

APPLICATION AND PERMIT FOR SEPTIC TANK T 60315

EXPIRES ONE YEAR FROM APPLICATION DATE

PERMIT ISSUED BY: JK

DATE

NUMBER

NAME OF OWNER

PARIS, KATHRYNE

OWNER'S MAILING ADDRESS

902 Buena Suerte, Fallbrook

PHONE

728-5713

ADDRESS OR LOCATION OF JOB

3096 Coral Tree Lane, Fallbrook, CA 92028

C.T. 188.00

ASSESSOR'S PARCEL NUMBER

123-081-44

SEPTIC TANK CONTRACTOR

11/10/82 2205374 997 0060315 A

PHONE

70.00 CHECK

SPACE BELOW FOR DEPARTMENTAL USE ONLY 70:00

PERMANENT ☒

TEMPORARY ☐

LAYOUT APPROVAL:

PERCOLATION TEST

SEEPAGE PIT (DEPTH)

SEPTIC TANK 1000 gal

TILE LINE 480' + 100% reserve

REMARKS see notes on layout

WATER SOURCE Fallbrook M.D.

Pittman

SANITARIAN

DATE

C/C B/A P/M Pcl #3, PM 7446

FIELD APPROVAL

REPAIR ☐ REMARKS

TYPE OF STRUCTURE: COMMERCIAL ☐ RESIDENTIAL ☒ 3 BR KK

DATE REQUESTED

DATE INSPECTED

APPROVED

DISAPPROVED

REINSPECTION NUMBER

DATE REINSPECTED

SANITARIAN'S APPROVAL

12/16/82 12-16-82 Pending

SAN 1

SANITARIAN

SAN DIEGO CO. DEPARTMENT OF HEALTH SERVICES
1700 PACIFIC HWY., SAN DIEGO, CALIF. 92101

☒ I hereby certify that I am the owner of the property for which I am applying for a permit to construct a subsurface sewage disposal system. I do not intend to sell or offer for sale this property within one year after completion of construction. I therefore request an exemption from the requirement that I have a proper contractor's license for such construction.

☐ I hereby certify that I am a contractor licensed in the State of California, to perform the specific tasks for which I am presently applying. My license is in full force and effect, and will remain so to the best of my knowledge throughout the duration of this project. My contractor's license is, as follows:

1. In the name of _____
2. State License No. _____
3. Classification: _____
(Class A or C42 required per Business & Professional Code, Chapter 9, Sec. 7056, and Calif. Administrative Code, Chapter 8 T - 16, Sec. 754.4)

I am informed and understand that any false information could result in a penalty of not more than \$500 for each violation, as provided in Business and Professional Code, Sec. 7031.5.

Signed: Karen Kulp Date 11/10/82

SEWAGE DISPOSAL LAYOUT FOR A SINGLE FAMILY RESIDENCE
COUNTY OF SAN DIEGO - DEPARTMENT OF PUBLIC HEALTH

260271

480 feet of open tile required
for 3 bedroom house plus
100% reserve lines to be
48" deep. Septic tank, open
and closed joint tile sys-
tem to be constructed in
accordance with the County
of San Diego Standard plans


LEGAL DESCRIPTION: PARCEL 3 OF PM 7446, IN THE
COUNTY OF SAN DIEGO, STATE OF CALIFORNIA, EXCEPTING
THE EASTERLY 19.00 FEET PER BDY. ADJ. NO 879-0314.

SITE ADDRESS CORAL TREE LANE
FALLBROOK, CA. 92028

APN 429-000-144
123-081-44

OWNER: KATHRYNE PARIS
902 BUENA SUERTE
FALLBROOK, CA. 92028
728-5713

PREPARED BY: HOLLOWAY ENGINEERING
P.O. BOX 585
VISTA, CA. 92083
(714) 941-1864




PARIS, Kathrynne

4/10/86
A structure including
deck or pool shall be installed
within 5' of the tank or
8' of the leach lines


I certify that the layout
drawing shows the location
of all public waterlines on
the lot and all public water-
lines that are within 20' of
the lot boundaries.

Ron Holloway

10-11-82
Layout approved
1000 gtl tank &
480' leach line for
3 br. house
Holloway



123-081-44



BLUE AQUA POOLS

845 RANCHO SANTA FE RD. SUITE 201, SAN MARCOS, CALIFORNIA 92086
California License # 442162

619:744-1960

619: 224-0377

